

# PIREG-C<sub>2</sub> Device Description: Resistance temperature controller with EtherNet/IP™ interface

# TOSS®



PIREG-C2 controller w. EtherNet/IP™



PIREG-CT-50 current transformer



EMV-Filter

## Applications:

Packaging machines for  
sealing plastic foils

## Contents:

<b>1. General, safety and warning instructions</b>	<b>3</b>	<b>4.1. Interface</b>	<b>17</b>
1.1. Note on the device description	3	4.1.1. Settings - Commands	17
1.2. Icons and symbols	3	4.1.2. Setting 1, heating ramp	17
1.3. General safety instructions	3	4.1.3. Setting 2, Tc setting	17
1.4. Application	3	4.1.4. Setting 2, calibration comparison time	17
1.5. Note on the heating conductor	4	4.1.5. Setting 4, temperature range	17
1.6. Note on the sealing transformer	4	4.1.6. Setting 5, calibration type	17
1.7. Note on the current transformer	5	4.1.7. Setting 6, transformer type	18
1.8. General assembly instructions	5	4.1.8. Setting 7, reference temperature	18
1.9. Maintenance	5	4.1.9. Setting 8, 8-point Tc correction	18
1.10. Validity	5	4.1.10. Setting 9, Single-point Tc correction	18
<b>2. Short description</b>	<b>6</b>	<b>4.2. LEDs</b>	<b>19</b>
<b>3. Operating states</b>	<b>7</b>	4.2.1. Power	19
<b>3.1. Calibration</b>	<b>7</b>	4.2.2. Heat	19
3.1.1. Initialisation	7	4.2.3. Calibration	19
3.1.2. Calibrating the input amplifier	7	4.2.4. Alarm	19
3.1.3. Determining the phase shift	7	4.2.5. Bus system:	19
3.1.4. Determining the reference resistance	7	4.2.6. Network:	19
3.1.5. Temperature comparison time	7	<b>4.3. Inputs</b>	<b>19</b>
3.1.6. Checking the reference resistance	7	4.3.1. Start input	19
3.1.7. Determining the P-factor	8	4.3.2. Calibration start input	19
3.1.8. 8-point Tc correction	8	4.3.3. Reset input	20
3.1.9. Single-point Tc correction	9	4.3.4. Target value input	20
3.1.10. P-factor correction	10	<b>4.4. Outputs</b>	<b>20</b>
<b>3.2. OFF state</b>	<b>10</b>	4.4.1. Uref output	20
3.2.1. Measurement pulse-pause	10	4.4.2. Actual value output	20
3.2.2. Calibration switching	11	4.4.3. Alarm output	20
3.2.3. Time log functions	11	4.4.4. OK output	20
<b>3.3. ON state</b>	<b>12</b>	4.4.5. ELR output	21
3.3.1. Temperature monitoring	12	<b>5. Operation</b>	<b>22</b>
3.3.2. Heating monitoring	12	<b>5.1. Communication</b>	<b>22</b>
3.3.3. Communication monitoring	13	5.1.1. RS232 and USB communication	22
3.3.4. P-factor monitoring	13	5.1.2. Addressed RS232 communication	22
3.3.5. Heating time limit	13	5.1.3. RS485 communication	22
3.3.6. Reference R20 value monitoring	13	5.1.4. RS232 com. with the ext. thermometer	23
3.3.7. Error causes - Display	14	<b>5.2. RS232 a. USB interface acknowledg.</b>	<b>24</b>
3.3.8. Error causes - Remedy	15	5.2.1. OK acknowledgement	24
3.3.9. Error memory	16	5.2.2. Error 1 acknowledgement	24
<b>4. Operation</b>	<b>17</b>	5.2.3. Error 2 acknowledgement	24
		5.2.4. Error 3 acknowledgement	24

5.2.5. Error 4 acknowledgement	24	6.4.1. AHUE parameter data	58
<b>5.3. RS485 interface acknowledgements</b>	<b>25</b>	6.4.2. BSTZ parameter data	59
5.3.1. OK acknowledgement	25	6.4.3. EINS parameter data	59
5.3.2. Command lock	25	6.4.4. EIPA parameter data	60
5.3.3. Command error	25	6.4.5. FEKO Parameterdaten	61
5.3.4. Transfer error	25	6.4.6. GWPA parameter data	61
5.3.5. Syntax or parameter error	25	6.4.7. HZBG parameter data	61
<b>5.4. Interface commands</b>	<b>25</b>	6.4.8. KAPK parameter data	62
Command overview	26	6.4.9. KASR parameter data	63
5.4.1. AHUE command	27	6.4.10. KONF parameter data	63
5.4.2. BRAT command	28	6.4.11. KPFK parameter data	64
5.4.3. BSMS Befehl	28	6.4.12. KTKZ parameter data	65
5.4.4. BSTZ command	29	6.4.13. PFUE parameter data	65
5.4.5. EINS command	29	6.4.14. RHZL parameter data	65
5.4.6. EIPA command	30	6.4.15. RRUE parameter data	66
5.4.7. FEKO command	31	6.4.16. TKEK parameter data	66
5.4.8. FESL command	32	6.4.17. TOKG parameter data	68
5.4.9. FESP command	32	6.4.18. TUEE parameter data	69
5.4.10. FEZU command	33	6.4.19. VERS parameter data	69
5.4.11. GADR command	34	6.4.20. WESE parameter data	69
5.4.12. GTYP command	35	6.4.21. ZPFA parameter data	70
5.4.13. GWPA command	35	6.4.22. ZPFE parameter data	70
5.4.14. HZBG command	36	6.4.23. ZYKL parameter data	70
5.4.15. ISTW command	36	<b>6.5. EtherNet/IP™ reset</b>	<b>72</b>
5.4.16. KANR command	37	6.5.1. Power-on reset	72
5.4.17. KAPA command	37	6.5.2. Factory settings	72
5.4.18. KAPK command	38	<b>6.6. Manual IP address</b>	<b>72</b>
5.4.19. KASR command	39	<b>6.7. EDS file</b>	<b>72</b>
5.4.20. KOKO command	39	<b>7. Installation and commissioning</b>	<b>73</b>
5.4.21. KONF command	40	7.1. Installation	73
5.4.22. KOUE command	41	7.2. 120/240V mains voltage changeover	73
5.4.23. KPFK command	42	7.3. Configuring the settings	74
5.4.24. KTKZ command	42	7.4. Connecting the PIREG-C2	74
5.4.25. MEPA command	43	7.5. Control inputs	74
5.4.26. PFUE command	43	7.6. Connecting to the mains voltage	74
5.4.27. RHZL command	44	7.7. Burning in the heating conductor	74
5.4.28. RRUE Befehl	45	7.8. When the contr. does not work corr.	74
5.4.29. SOLW command	45	7.9. Current Transformer	75
5.4.30. STEU command	46	<b>8. The heating conductor</b>	<b>76</b>
5.4.31. STKA command	46	<b>9. Technical data</b>	<b>77</b>
5.4.32. STRS command	47	9.1. Controller	77
5.4.33. STST command	47	9.2. Current transformer	79
5.4.34. TKEI command	47	9.3. Potentiometer	80
5.4.35. TKEK command	48	9.4. Analogue display	80
5.4.36. TOKG command	48	9.5. Sealing transformer	80
5.4.37. TUEE command	49	9.6. External thermometer DTM3000	80
5.4.38. UIMW command	49	9.7. Ordering codes	80
5.4.39. VERS command	50	9.8 Housing	81
5.4.40. WESE command	50	9.8.1. PIREG-C2 housing	81
5.4.41. ZPFA command	52	9.8.2. Current transformer housing	81
5.4.42. ZPFE command	52	9.8.3. Potentiometer housing	81
5.4.43. ZUST command	53	9.8.4. Analogue display housing	81
5.4.44. ZYKL command	53	9.9. Spare parts	81
<b>6. EtherNet/IP™ bus system</b>	<b>55</b>	<b>10. Connection diagrams</b>	<b>82</b>
Command overview	55	10.1. PIREG-C2 with ext. solid-state relay	82
<b>6.1. Device data</b>	<b>56</b>	10.2. PIREG-C2 with internal thyristors	82
<b>6.2. Process data</b>	<b>57</b>	10.3. RS232 / RS485 connection – interf.	82
6.2.1. Read process data, T → O	57	<b>11. Application note</b>	<b>83</b>
6.2.2. Write process data, O → T	57	11.1. Application instructions	83
<b>6.3. Configuration parameters</b>	<b>58</b>	<b>12. Disposal</b>	<b>84</b>
<b>6.4. Parameter data</b>	<b>58</b>		

## 1. General, safety and warning instructions

### 1.1. Note on the device description

The purpose of this device description is to ensure optimum installation, commissioning, operation and maintenance of the PIREG-C2 and must be read prior to carrying out any of the actions described. Keep the device description handy and accessible to all users for possible referencing. Pass this manual on to future users of the PIREG-C2.

All necessary settings are described in this device description. Should difficulties nevertheless arise during commissioning or operation, please do not carry out any unauthorised manipulations. You could put yourself and others at risk as well as jeopardize your warranty claim. In such cases, please contact us immediately:

**TOSS**<sup>®</sup> GmbH & Co. KG  
-Verpackungssysteme-  
Danziger Straße 15  
D-35418 Alten-Buseck

Phone: +49 (0) 64 08 - 90 91 - 0  
Fax: +49 (0) 64 08 - 43 55  
E-mail: [info@toss-gmbh.de](mailto:info@toss-gmbh.de)  
Internet: [www.toss-gmbh.de](http://www.toss-gmbh.de)

### 1.2. Icons and symbols



**Danger (EN):** Indicates a hazard that could result in personal injury. Whenever this symbol is used, the device description must be consulted and the accompanying instructions must be observed and followed in order to avoid hazards.

**Danger (FR):** Indique un danger pouvant entrainer des atteintes à la santé des personnes. Lorsque ce symbole est utilisé, la description de l'appareil doit être consultée et les indications doivent être observées et respectées afin d'éviter toute mise en danger.



**Danger (EN):** Indicates a hazard due to electrical current. Failure to observe the safety instructions may result in serious or fatal injuries.

**Danger (FR):** Indique un danger d'électrocution. Un non-respect de ces indications de sécurité entraine un danger de blessures graves, voire mortelles.



**Danger (EN):** Indicates a hazard due to hot surfaces or burn up that could result in personal injury.

**Danger (FR):** Indique un danger dû aux surfaces brûlantes, voire rougeoyantes pouvant entrainer des atteintes à la santé des personnes.



**Note (EN):** Indicates particularly important information which, if ignored, can lead to material damage, for example.

**Indications (FR):** Indique une information particulièrement importante pouvant entrainer des dégâts matériels en cas de non-respect.

### 1.3. General safety instructions



**EN:** The safety instructions and warnings given in this description must be followed to guarantee safe operation of the equipment. The equipment can be operated without impairing the operational reliability if the conditions stated in the technical specifications are observed.



The equipment may only be installed and started-up by suitably trained personnel.

Maintenance and repair of the equipment may only be carried out by trained personnel, who are familiar with the dangers and guarantee conditions.

**FR:** Les indications et mises en garde contenues dans cette description doivent être respectées afin de garantir un fonctionnement sûr. Si les consignes de sécurité de fonctionnement sont respectées, l'appareil peut être exploité aux conditions mentionnées dans les données techniques.

Cet appareil ne peut être installé et mis en service que par un personnel qualifié en technique électronique !

Les travaux d'entretien et de réparation ne peuvent être effectués que par des personnes formées et spécialistes familiarisées avec les dangers liés à l'appareil et les conditions de garantie.

### 1.4. Application



**EN:** The PIREG-C2 resistance temperature controller may only be used for the heating and temperature control of heating conductors as specified via isolating transformers in accordance with the regulations, notes and warnings contained in this description.

Non-observance of the instructions or incorrect use of the equipment can result in impairment of the safety or overheating of the heating conductor, the electrical wiring or the transformer.

**FR:** Le régulateur de température à résistance PIREG-C2 ne doit être utilisé que pour le chauffage et la régulation de température de conducteurs de chaleur expressément conçus à cet effet par l'intermédiaire de transformateurs de séparation conformément aux prescriptions, indications et mises en garde mentionnés dans cette description.

Le non-respect ou l'utilisation non conforme peut compromettre la sécurité ou entrainer le surchauffe des conducteurs de chaleur, des câbles électriques, du transformateur, etc.

### 1.5. Note on the heating conductor

A basic precondition for the function and safe operation of the complete heating system is the application of suitable heating conductors.

The positive temperature coefficient of the heating conductor used must be equal or greater than the positive temperature coefficient set at the PIREG-C2. The appropriate temperature coefficient of the heating conductor must be set at the PIREG-C2 via the interfaces. The temperature coefficient of the heating conductor must be positive over the entire temperature range.

<b>Alloy L:</b>	$T_{c1} = 7,46 \times 10^{-4} \text{ 1/K}$	$T_{c2} = 0$	$T_{c3} = 0$
<b>Alloy M:</b>	$T_{c1} = 8,62 \times 10^{-4} \text{ 1/K}$	$T_{c2} = 0$	$T_{c3} = 0$
<b>Alloy A20:</b>	$T_{c1} = 10,8 \times 10^{-4} \text{ 1/K}$	$T_{c2} = 0$	$T_{c3} = 0$
<b>Norex:</b>	$T_{c1} = 48,3 \times 10^{-4} \text{ 1/K}$	$T_{c2} = -6,12 \times 10^{-6} \text{ 1/K}^2$	$T_{c3} = 2,80 \times 10^{-9} \text{ 1/K}^3$
<b>Alloy A20C:</b>	$T_{c1} = 12,65 \times 10^{-4} \text{ 1/K}$	$T_{c2} = 0$	$T_{c3} = -0,70 \times 10^{-9} \text{ 1/K}^3$
<b>Alloy A20D:</b>	$T_{c1} = 12,55 \times 10^{-4} \text{ 1/K}$	$T_{c2} = 0$	$T_{c3} = 0$
<b>Variabel:</b>	$T_{c1} =$ $+3,00 \dots +99,99 \times 10^{-4} \text{ 1/K}$	$T_{c2} =$ $-99,99 \dots +99,99 \times 10^{-6} \text{ 1/K}^2$	$T_{c3} =$ $-99,99 \dots +99,99 \times 10^{-9} \text{ 1/K}^3$



**Caution (EN):** Using heating conductors with too low a temperature coefficient, or adjusting the controller to a temperature coefficient that is too high, can result in uncontrolled overheating or **melting** of the heating conductor.

**Attention (FR):** Si un conducteur de chaleur est utilisé avec un petit coefficient de température ou qu'un coefficient de température trop grand est réglé sur le régulateur, les conducteurs de chaleur vont chauffer de manière incontrôlée et peuvent aller jusqu'à **fondre**.

Heating conductors with a lower temperature coefficient can also be used when correcting the setpoint voltage (→ 4.1.3.).

Temperature regulation of heating conductors connected in parallel must be more precise than of heating conductors connected in series. However, the wiring must be strictly symmetrical and performed in such a way that no overcurrent arises when two heating conductors on opposite sides contact each other.

If series-connected heating conductors have to be used, the effect on the overcurrent reaction should be taken into consideration if two opposite sealing bands touch each other.

### 1.6. Note on the sealing transformer

The sealing transformer must be configured according to EN 61558 (VDE 0570) resp. UL 5085 (isolating transformer with reinforced isolation) and in a single-chamber design. All types and designs that comply with the standards can be used as sealing transformers. The induction in the transformer's iron core must not be reduced as is normally the case with primary side thyristor operation. A transformer with low losses are disrupted less on the secondary side than with transformers that have low energizing currents. Thus in applications with short heating and sealing times, stiff and generally larger transformers should be used. Where a great deal of sealing is to be performed, a transformer with a primary voltage of 400 V is advantageous, because this way, the switching capacity of the PIREG-C2's internal actuator is more likely to be sufficient and an external actuator with solid-state relay will not have to be used.



**Caution (EN):** There must be sufficient protection against accidental contact if the transformer is installed in a machine frame. Furthermore, ensure that water, cleaning liquids or conducting liquids do not come into contact with the transformer. The conductor wiring cross sections should be designed to match the actual currents. Non-observance of these notes may result in impairment of the electrical safety.

**Attention (FR):** Si le transformateur est placé dans le corps de la machine, une protection suffisante contre les contacts accidentels doit être prévue. De plus, il convient d'empêcher l'eau, les solutions de nettoyage ou les liquides conducteurs d'entrer en contact avec le transformateur. Les sections des câbles doivent être conçues en fonction des courants réels. Le non-respect de ces instructions compromet la sécurité électrique.

For best results, the transformer's performance and the secondary voltage must be suited to the heating conductor. A short heat-up period is reached with of a high transformer output voltage. However, the voltage selected should not be too large so that not less than 12 controller measurements are needed for a target temperature increase of 300°C when heating up (heat-up period  $\geq 240$  ms). For smaller heat-up curves, correspondingly fewer measurements are necessary. (The PIREG-C2 takes a measurement every 20 ms while heating).

The larger the transformer's secondary voltage for a given heating conductor, the more energy is fed into the heating conductor, even in the OFF state. This is done by means of temperature measuring impulses, which the controller regularly sends to the heating conductor. Therefore, the higher the secondary voltage of the transformer the greater is the difference between the resting temperature and the ambient temperature in the OFF state.

### 1.7. Note on the current transformer



**EN:** The current transformer is an essential part of the control system. Only Toss current transformers may be used. The current transformer may only be operated with ballast resistance. The ballast resistance is integrated into the PIREG-C2. The current transformer must be mounted in such a way that magnetic leakage fields from the sealing transformer or other leakage fields do not affect the measurement.

**FR:** Le transformateur de courant fait partie du système de régulation. Seuls les transformateurs de courant Toss peuvent être utilisés. Le transformateur de courant ne doit être utilisé qu'avec une résistance ohmique apparente. La résistance ohmique apparente est intégrée dans le PIREG-C2. Le transformateur de courant doit être monté de telle sorte que les champs magnétiques de dispersion du transformateur de soudage ou d'autres champs de dispersion n'influencent pas la mesure.



**Caution (EN):** The used cable to the heating conductor can heat up the current transformer.

**Attention (FR):** Le conduit utilisé allant vers le conducteur de chaleur peut chauffer le transformateur de courant.

### 1.8. General assembly instructions

The PIREG-C2 resistance temperature controller is only suited for use in a switch cabinet. Open operation is not permitted.

The controller as well as the current transformer are mounted on 35mm mounting rails as per EN 60715 (EN 50022). When assembling the controller on the mounting rail, there must be a distance of at least 20 mm to the next device.

Heat dissipation from neighbouring devices must be taken into account (note the ambient temperature specifications).

### 1.9. Maintenance

The PIREG-C2 resistance temperature controller does not require any special maintenance. However, an occasional check or tightening of the connection terminals is recommended. Dust deposits on the controller can be removed with dry compressed air once the power has been switched off.

### 1.10. Validity

The first device type (vw) delivered was the series 1.00 with the program version 1.01 for the electrically separate side (ggg) and 1.01 for the instrumentation side (mmm). Supplements in this description which are only valid from a later version and include the version, the notation Vvvv/ggg/mmm, e.g. V1.00/1.01/1.01 from which they are valid. The device and program versions are read by command (VERS) via the interfaces.

## 2. Short description

The PIREG-C2 resistance temperature controller with an EtherNet/IP interface as bus system is used to control the temperature of heating conductors for the heat-impulse sealing of foils. The sealing transformer is used by the PIREG-C2 on the primary side. The internal actuator or an external solid-state relay which is controlled by the PIREG-C2 can be used. The heating conductor is fed from the secondary side of the transformer. The measuring signals are received directly at the heating conductor and are made available to the controller.

The temperature coefficient  $T_c$  of the heating conductor must be positive. This increases the resistance of the heating conductor when heated. This effect is used for temperature control. The temperature controller measures and regulates the resistance of the heating conductor. The temperature coefficient  $T_c$  is a material constant that depends on the alloy used for the heating conductor. The actual temperature is determined by measuring the voltage and current.

The PIREG-C2 operates as a proportional control unit that independently determines the P-factor (the control amplification) for the controlled system of a process during calibration itself. The controlled system consists of a sealing transformer and a heating conductor. The P-factor determined during calibration can afterwards still be corrected by command or via the target value input (→ 5.4. and 6.4.). An additional compensation function allows to minimise the permanent control deviation typical of a proportional controller.

The PIREG-C2 is operated either conventionally with a setpoint potentiometer or setpoint voltage, actual value instrument, LEDs and switches or digital signals (→ 4.2. - 4.4.), or via the EtherNet/IP interface, the RS232, RS485 or USB interface (→ 5. and 6.) with which the PIREG-C2 is equipped. The PIREG-C2 can only be set via the EtherNet/IP interface or the RS232, RS485 or USB interface. Combinations of both types of operation are possible.

The PIREG-C2 is set to the temperature coefficients (→ 5.4. and 6.4.). If the temperature coefficient values differ, the setpoint voltage must be corrected. The PIREG-C2 can also determine the actual temperature coefficient of a heating conductor itself by means of a temperature coefficient correction ( $T_c$  correction) (→ 5.4. and 6.4.). Connect the PIREG-C2 via the RS232 interface to an external thermometer, DTM3000 (from V1.01/1.16/1.10) or previous TM6, which measures the actual temperature of the heating conductor to simplify the  $T_c$  correction. Depending on the setting, the PIREG-C2 can operate up to a temperature range of 500 °C.

During calibration, the controller sets itself to the secondary voltage of the transformer and the current through the heating conductor. The secondary voltage of the transformer may be within a range of 1...120 V. The current measured with a current transformer can range from 20 to 500 A. The calibration values can be stored in the controller, so that there is no need for renewed calibration and start-up time after switching on the power when conditions have not changed.

The PIREG-C2 can conduct the calibration at room temperature (always taken to be 20°C) as well as at any other ambient temperature between 0 - 50 °C. The controlled is informed of the actual reference temperature from outside. This is advantageous in the case of constant sealing temperatures with different environmental conditions (→ 5.4. and 6.4.).

High quality sealing transformers, such as toroidal core transformers, are switched by the PIREG-C2 on the primary side. A smooth switching procedure is employed that compensates for the remanence of the sealing transformer. An initialising remanence setting is made automatically after switching on the power and following calibration. Only a short remanence setting lasting 40 ms for EI core transformers and 80 ms for toroidal core transformers is needed before each sealing process. If, with toroidal core transformers, the pause between two sealing processes is longer than 10 minutes, the remanence setting takes 160 ms. The remanence is the residual magnetization in the transformer's iron core. During the initial remanence setting procedure, the heating conductor has to be heated for a short time to approx. 40 to 70 °C. The PIREG-C2 itself uses a phase angle controller to regulate the temperature.

## 3. Operating states

### 3.1. Calibration

During calibration, the PIREG-C2 automatically adapts to the sealing transformer/heating conductor combination. At the same time, the voltage "Ur" at the heating conductor and the current "Ir" through the heating conductor are measured every second. In this condition, the blue "calibration" LED is lit up and the calibration OK signal is reset. The calibration OK signal is sent by the OK output if the appropriate function has been set by command (KONF). The OK output is factory set to the Calibration-OK message feature. The actual value output is used to display the individual steps. The actual value output is updated every second.

The calibration procedure with the individual states is available as data at the EtherNet/IP interface and the other interfaces. The controlling PLC can additionally track the calibration process by observing the actual value output at terminal 17 and can recognise the end of the calibration from the calibration OK signal. The sealing controls are then released. During calibration steps 1 to 7, no "Start" signal may be given as otherwise the PIREG-C2 will interrupt the calibration with error 2.

**The calibration process will undergo the following steps:**

**3.1.1. Initialisation:** During initialisation, the PIREG-C2 determines the data necessary for calibration. In addition, it checks the selected temperature coefficient for dynamics and continuity in the selected temperature range. Should the dynamics and continuity exceed the permitted limits, the PIREG-C2 will stop the calibration procedure with Error 13 (parameter error). The reference temperature still set is checked in the permitted range of 0...50 °C. If the reference temperature is outside this range, the PIREG-C2 will also stop the calibration procedure with Error 13 (reference temperature selected too large).

**3.1.2. Calibrating the input amplifier:** The input amplifiers for Ur and Ir are adjusted in steps to the voltage and current at the heating conductor. In the first step, the required modulation reserve for the sealing transformer/heating conductor combination is determined automatically if not set manually by command (KASR).

During this step, different voltage values are applied to the actual value output every second. The measured current or voltage value is connected alternately. The measured value of the current is displayed in the 0 - 5 V range, the voltage in the 5 - 10 V range. The zero point of the measured values is 5 V. At the beginning of the calibration, the amplifiers (for Ur and Ir) are initialised with minimum amplification. At the end of the calibration procedure, if the adjustment has been made successfully, the range for the displayed current value is from 1.66 - 3.33 V and the range for the displayed voltage value is from 6.66 - 8.33 V.

**3.1.3. Determining the phase shift:** During this step, the transformer-dependent phase shift between Ur and Ir is measured and corrected. The controller automatically sets the optimum scan times for Ur and Ir. The actual value output displays the phase shift. A signal of approx. 5 V corresponds to the ideal value.

**3.1.4. Determining the reference resistance:** (→ 5.4. and 6.4.) The reference resistance of the heating conductor (Rref) is determined in this step. The controller assumes a constant reference temperature of 20 °C for calibration. Alternatively, a variable reference temperature of 0...50 °C can be entered as nominal value (50 °C = 1.66 V at 300 °C and 1.00 V at 500 °C). While the calibration is being initialised, the PIREG-C2 reads the variable reference temperature, depending on the settings. During calibration, the heating conductor must be at the reference temperature to ensure that regulation is exact. By standardizing the voltage signal (Ur) and the current signal (Ir), the reference resistance for the different temperature coefficients is always within the same resistance range. If 20 °C has been selected as the reference temperature, then heating conductor's R20 is directly determined as the reference resistance. If a heating conductor temperature other than 20 °C has been selected for calibration, then the determined reference resistance corresponds to the temperature coefficient above or below the value for the R20. The reference resistance is displayed for one second at calibration stage 4 at the actual value output. At a reference temperature of 20 °C, the voltage at the actual value output is 7...8 V. At a variable reference temperature the voltage will be between 6 and 10V.

**3.1.5. Temperature comparison time:** (→ 5.4. and 6.4.) The aim of the temperature comparison time is to ensure that the comparator resistance can only be determined when the heating conductor has completely cooled down. During this comparison time, the signal at the actual value output declines from 10 V to 0 V. Times of 15 or 30 s can be chosen for the temperature comparison time.

**3.1.6. Checking the reference resistance:** The comparator resistance is checked after the temperature reference time is finished. If calibration takes place on a heating conductor that has cooled down still further during the temperature comparison time, the entire calibration will be discarded and the procedure automatically restarted. Once the reference resistance has been successfully checked, the PIREG-C2 calculates the R20 (resistance at 20 °C) of the heating conductor from the type of reference temperature set, the temperature coefficients selected and the reference resistance (Rref) determined.

The comparator resistance measured is displayed for one second at the actual value output. The same voltage must be set at the actual value output as when the reference resistance was determined (→ 3.1.4).

**3.1.7. Determining the P-factor:** The P-factor of the sealing transformer/heating conductor combination is determined by heating with a constant correction variable. The heating conductor is either warmed by a maximum of approx. 60 K or charged for a maximum of 120 network periods with a defined control value. The total amplification of the control system is calculated from the measurement of the power fed into the heating conductor and the measurement of the temperature increase of the heating conductor. The P-factor for the PIREG-C2 is calculated from this.

In the case of adverse conditions of the sealing transformer/heating conductor combinations or the public supply the P-factor of the PIREG-C2 can be corrected manually within a range of 30...110 % (→ 5.4. and 6.4.).

The P-factor monitoring which is set by command (PFUE) is used to monitor the P-factor determined by PIREG-C2 on a valid range (→ 3.4.4., 5.4. and 6.4.).

**3.1.8. 8-point Tc correction:** The 8-point temperature coefficient correction function can be used to correct tolerances of the temperature coefficients. These result from the dispersion of the metallurgical composition of the heating conductors.

In calibration stage 8, the PIREG-C2 gradually heats up the heating conductor in eight temperature increments or stages. The PIREG-C2 compares its actual value temperature with the actual temperature of the heating conductor, which it receives as a target value or directly as a measured temperature value.

The size of each increment is a result of the selected temperature range. The first temperature increment is always 50 °C. The temperature of the eighth temperature increment falls 20% below the final value of the temperature range. The six other temperature increments are equidistant between these points.

- For the 300°C temperature range the points are: 50, 77, 104, 131, 159, 186, 213 and 240 °C.

- For the 500°C temperature range the points are: 50, 100, 150, 200, 250, 300, 350 and 400 °C.

The actual temperature of the heating conductor must be sent back externally to the PIREG-C2 as a target value or directly as a measured value of the external thermometer. Deviations of up to ±20 % between the calculated actual value temperature and the actual temperature of the heating conductor can be corrected (→ 4.1.9., 5.4. and 6.4.). The correction process is controlled with the "Start" signal or by command (STST).

The 8-point Tc correction can be saved by command (STKA) so that it doesn't need to be repeated after a new calibration but only when the heating conductor is replaced.


#### **Performing the 8-point Tc correction:**

- **manual operation:** The actual temperature of the heating conductor is reported back to the PIREG-C2 via the set value input. The next temperature step is switched to with the rising edge of the "Start" signal. After the heating conductor has reached a uniform temperature the temperature set as the target value is taken over as the actual temperature of the heating conductor with the falling edge of the "Start" signal. After heating to the next temperature stage, only accept the temperature once the heating conductor itself has reached the specified temperature. The actual value output indicates the corresponding, not yet corrected actual value temperature of the PIREG-C2.

At the beginning of the 8-point Tc correction, the "Calibration" LED flashes while the communication setup time at a cycle rate of 1 Hz, while the PIREG-C2 tries to establish the connection to the external thermometer.

- **manual operation with the external thermometer:** The 8-point Tc correction is controlled with the "Start" signal as described above. The actual temperature of the heating conductor is measured with the external thermometer which is connected to the RS232 interface of the PIREG-C2. The PIREG-C2 automatically tries to establish a connection with the external thermometer for the communication setup time at the beginning of the 8-point Tc correction. The "Calibration" LED flashes at a cycle rate of 1 Hz during connection establishment and when the connection to the external thermometer has been established.

- **automatic 8-point Tc correction:** The PIREG-C2 must be connected to the external thermometer and the set value for the heating time must be greater than zero for the automatic 8-point Tc correction. The heating time is the period until the heating conductor has reached a uniform temperature at a temperature stage. The heating time is set either in the Reset state or by command (KTKZ) (→ 5.4. and 6.4.). The PIREG-C2 undergoes the automatic 8-point Tc correction independently and remains at each temperature stage for the preset heating time.



**Figure 1: Calibration process**

The controller must undergo calibration steps one to seven for each calibration. Step eight is a selectable calibration function (→ 3.1.8.). If an error occurs during the individual calibration steps, the PIREG-C2 stops the calibration process and then restarts the calibration. Calibration is stopped with an error message after attempt five was not successful (→ 3.4.).

Calibration must be carried out when the heating conductor has reached a temperature of approx. 20 °C or the externally determined calibration temperature to ensure that the R20 reference resistance of the heating conductor is calculated correctly. The time required for a calibration process depends on various factors. The calibration duration is determined by the voltage at the heating conductor, the current flowing through the conductor, the phase shift from  $U_r$  and  $I_r$  and the P-factor of the sealing transformer/heating conductor combination. The controller needs maximum 48 or 63 seconds for one calibration process.

If the calibration process is not successful, e.g. because the P-factor has been determined incorrectly, the controller makes another four attempts before reporting an error. In this case, the maximum calibration time can amount to 240 or 315 s, depending on the temperature comparison time.

If the calibration mode “**new calibration**” is chosen, the controller always switches to calibration immediately after a power-on or after a reset and carries out a new calibration. Calibration can also be started in the OFF or error state with the signal “Calibration Start”.

If the calibration mode “**Save**” is chosen, the controller switches to calibration when in an OFF or error state or before power-on only when the “Calibration Start” signal is applied. In this type of calibration, the calibration values are saved in a non-volatile memory and are loaded immediately after a power-on or the “Reset” signal.

The operator or the controlling PLC can recognize the end of a successful calibration process as follows:

- **without 8-point Tc correction:** By observing the actual value on the characteristic voltage curves (→ Figure 1, steps 5, 6 and 7 with subsequent remanence and subsequent cooling of the heating conductor from approx. 50 °C to approx. ambient temperature).

- **with 8-point Tc correction:** As before, but with subsequent 8-point Tc correction (→ step 8). After the last correction step, the controller is ready for operation. The PLC must then wait until the temperature of the heating conductor has cooled down.

- **with calibration OK message:** The calibration OK message is reset when calibration is started and reset at the end of successful calibration. The calibration OK message is the factory setting of the OK output, which can be changed by command (KONF).

**3.1.9. Single-point Tc correction:** With the single-point temperature coefficient correction the tolerances of the temperature coefficient of the heating conductor can be corrected for just one operating point. For this operating point the actual temperature of the heating conductor is reported back to the PIREG-C2 as actual value or directly as measured value of the external thermometer from outside. The single-point Tc correction is carried out outside the standard calibration and is started from the OFF state. Single-point Tc correction has an OFF and an ON state. After the single-point Tc correction was started, the PIREG-C2 is in the OFF state. When the PIREG-D is in the ON state, the heating conductor is heated to the temperature which was set as target value in the OFF state. After heating, only accept the temperature once the heating conductor itself has reached the specified temperature. The actual value output indicates the not yet corrected actual value temperature of the PIREG-C2. The single-point Tc correction finishes upon exiting the ON state. The correction process is controlled with the “Start” signal or by command (STST). Deviations of up to  $\pm 20$  % between the calculated actual value temperature and the actual temperature of

the heating conductor can be corrected. The single-point Tc correction can only be performed if an 8-point Tc correction was not carried out during calibration. The single-point Tc correction is reset at each calibration.

The single-point Tc correction can be saved by command (STKA) so that it doesn't need to be repeated after a new calibration but only when the heating conductor is replaced.

#### **Performing the single-point Tc correction:**

- **manual operation:** The single-point Tc correction is started by command (STKA). If the pulse-control was configured by command (KONF) for the calibration start input (5), the single-point Tc correction can also be started by applying a high signal for less than one second (→ 5.4. and 6.4.). The PIREG-C2 retains the temperature set as set value as the temperature of the operating point as long as a low-signal is applied as "Start" signal. When a high signal is applied as "Start" signal the PIREG-C2 heats the heating conductor to the temperature of the operating point. Now the actual temperature of the heating conductor is set as target value. When a low-signal is applied again as "Start" signal, the PIREG-C2 calculates the correction factors for the single-point Tc correction and saves these values if "Save" was selected as the calibration type.

- **manual operation with the external thermometer:** The single-point Tc correction is started and controlled as described above. The actual temperature of the heating conductor is measured with the external thermometer which is connected to the RS232 interface of the PIREG-C2. The PIREG-C2 automatically tries to establish a connection with the external thermometer at the beginning of the single-point Tc correction. The Calibration LED flashes at a cycle rate of 1 Hz when connection to the external thermometer has been established.

- **automatic single-point Tc correction:** The PIREG-C2 must be connected to the external thermometer and the set value for the heating time must be greater than zero for the automatic single-point Tc correction. The heating time is the period until the heating conductor has reached a uniform temperature in the ON state of the single-point Tc correction. The heating time is set either in the Reset state or by command (KTKZ) (→ 5.4. and 6.4.). Automatic single-point Tc correction is started as described above for manual operation. The PIREG-C2 undergoes the automatic single-point Tc correction independently and remains in the ON state for the preset heating time.

**3.1.10. P-factor correction:** The P-factor correction is used for subsequent manual correction of the calibrated P-factor (→ 3.1.7.) in the case of very unfavourable conditions of the sealing transformer/heating conductor combinations or the public supply. The correction range is 30...250 % (from V1.01/1.09/1.07).

The P-factor correction can be set by command (KPFK). The P-factor correction value will not be reset during a calibration as it is system dependent.

### **3.2. OFF state**

In the OFF state, the PIREG-C2 regularly measures the resistance of the heating conductor and from this value determines the temperature and forwards this to the actual value output.

For each resistance measurement a positive and negative power line half-wave of the same fixed angle of current flow (1.8 ms at 50 Hz mains frequency) is applied to the transformer. The time intervals of the measurements depend on the temperature of the heating conductor. When the heating conductor has reached a temperature of 20 °C, the measuring interval is 1.5 s. At a temperature of 300 °C, the measuring interval is only 100 ms.

The heating conductor is heated in the OFF state and dependent on the voltage by the energy introduced when measuring the resistance.

The controller switches from the OFF state to the ON state as soon as the "Start" signal is applied. When the "Calibration Start" signal is applied the PIREG-C2 returns to calibration and to the OFF state after the end of a successful calibration. The PIREG-C2 then stays in the OFF state even when the "Calibration Start" signal is still applied (evaluation of the rising edge).

If the pulse control was configured by command (KONF) for the calibration start input (5), the PIREG-C2 switches in the single-point Tc correction when a high-signal is applied for less than one second.

**3.2.1. Measurement pulse-pause:** In the off state, the measurement pulse-pause can be switched on and off per command (MEPA). When measurement pulse-pause is activated, the PIREG-C2 stops sending measurement pulses to the sealing transformer in order to determine the temperature of the heating conductor.

The actual value output indicates the value determined last. Only the monitoring of the mains voltage and the device function is still active. All other monitoring functions that relate to the measurement pulses are disabled.

The measurement pulse-pause is for applications in which the primary or secondary circuit of the sealing transformer has to be interrupted during operation without the PIREG-C2 switching to the error state.

With the start of a sealing process, a calibration or a reset, the measurement pulse-pause is automatically terminated.


**3.2.2. Calibration switching:** The PIREG-C2 offers the possibility to save eight calibrations and to switch between them by command (KANR). In the off state, a changeover between the eight calibrations is made by command (KANR). Calibration 1 is always active after power on or reset.

The heating conductors of the eight calibrations must be the equal for the temperature coefficient, temperature range and the other calibration settings. A possible temperature coefficient correction is performed separately for each calibration. The PIREG-C2 performs its own calibration for each heat conductor, which is also stored separately.

**3.2.3. Time log functions:** The PIREG-C2 offers the possibility to record the time behaviour of a sealing process, e.g. to detect long-term changes (from V1.01/1.09/1.06). The time log functions are used to record the time behaviour of the sealing system, which essentially consists of the sealing transformer and heating conductor, during a sealing process. The recording is carried out separately for the heating phase in the on-state and the subsequent cooling phase in the off-state.

**- Heating phase:** The recorded values for the previous heating phase are read out by command (ZPFE) in the off-state for the previous on-state. The following values are recorded for the heating phase:


- Actual temperature value before heating.
- Target temperature value before heating.
- Heating-up time; the heating-up time ends when the actual value exceeds 95% of the target value.
- Sealing time; the sealing time starts when the actual value exceeds 95% of the target value.
- Average of the actual temperature value during the sealing time.
- Heating time; the heating time starts and ends when the start signal is applied and removed.



**Figure 2: Time log function – Heating phase**

**- Cooling phase:** The recorded values for the cooling phase should be read out by command (ZPFA) in the off-state as soon as the actual temperature value has fallen below 50°C or directly before the next on-state. The following values are recorded for the cooling phase:

- Actual temperature value at the beginning of the off-state.
- Cooling time; the cooling time ends when the actual value falls below 50°C.



**Figure 3: Time log function – Cooling phase**

### 3.3. ON state

In the ON state, the PIREG-C2 controls the temperature of the heating conductor in accordance with the target value. A phase angle controller is used. The controller returns to the OFF state when the "Start" signal is removed.

### 3.4. Error state

The error state is indicated on the PIREG-C2 only when an error occurs. The controller monitors the line voltage, the temperature of the heating conductor, the values of the voltage and current measurements at the heating conductor and the calibration parameters.

The alarm output is set in the error state. In the event of a power line error (error 3), actuation takes place with a delay of 2 seconds. In the error state, the alarm and calibration LED's are triggered with different cycle rates of 1 or 4 Hz depending on the error that has occurred (→ Table 1). The actual value output is also cycled in some error cases. The voltage at the actual value output then changes every second between the voltages applicable to the different errors (→ Table 1). The error state can only be cancelled by switching off the power supply, the „Reset“ signal and „Calibration Start“. With errors 1 and 3 the error state cannot be cancelled with the "Calibration Start" signal.

In the OFF state, after switching on the power or following a reset, errors 4 - 13 are only reported by the LEDs and actual value output; however, the alarm output is not set in the factory default. This way, a calibration error does not lead to a machine malfunction when switching on. The factory setting can be changed with a command (KONF).

**3.4.1. Temperature monitoring:** The monitoring of the temperature is an additional monitoring function which is activated and adjusted with a command (TUEE). The actual temperature value is monitored during the sealing process in the ON state to ensure that it is within a temperature OK range. If the actual value leaves the temperature OK range during the sealing process after the stabilisation time has ended the PIREG-C2 will go to error state with error 8. The stabilisation time begins as soon as the actual value has reached the temperature OK range. In the event of a change of the target value by more than 2 °C, the stabilisation period is restarted.





Figure 4: Temperature monitoring


**3.4.2. Heating monitoring:** The monitoring of the heating is an additional monitoring function which is activated and adjusted with the command (AHUE). With this function the temperature rise is monitored after the "Start" signal was applied.

- **Variante 1:** Under variant 1, the PIREG-C2 monitors the heating time to a maximum value. If the actual value of the temperature does not reach the temperature OK range within the set heating time, the PIREG-C2 switches to the error state with error 8.



**Figure 5: Heating monitoring - Variant 1**

**- Variant 2:** Under variant 2, the PIREG-C2 monitors the heating time to a minimum and maximum value. If the actual value of the temperature does not reach the temperature OK range within the set time window, the PIREG-C2 switches to the error state with error 8.



**Figure 6: Heating monitoring - Variant 2**

**3.4.3. Communication monitoring:** The monitoring of the communication is an additional monitoring function for the three interfaces of the PIREG-C2 and is activated and set with a command (KOUÉ) for each interface individually. This function monitors communication via the interfaces for interruptions. If the communication via the interface is interrupted for a longer time than the set downtime, then the PIREG-C2 switches to the error state with error 9.

**3.4.4. P-factor monitoring:** The P-factor monitoring is an additional monitoring function for the calibrated P-factor (→ 3.1.7.), which is set with a command (PFUE). This function is used to monitor the calibrated P-factor for a minimum and maximum value of an OK range. If the calibrated P-factor is outside the OK range, the PIREG-C2 will go to the error state with error 10.

A calibration with the intended sealing transformer/heating conductor combination should first be carried out to determine the OK range of the P-factor monitoring. The calibrated P-factor of PIREG-C2 can be read back by command (PFUE). The upper and lower limits should be set according to this value. In addition to the sealing transformer/heating conductor combination, the level of the mains voltage during calibration has an impact on the calibrated P-factor of PIREG-C2.

**3.4.5. Heating time limit:** The heating time limit is a monitoring function to prevent unintentional continuous heating of the PIREG-C2 due to an operating error. A command (HZBG) activates the monitoring function and sets the maximum heating time. If the set maximum heating time is exceeded in the ON state, the PIREG-C2 goes to error state with error 2 and stops heating.

**3.4.6. Reference R20 value monitoring:** The reference R20 value monitoring is a monitoring function for the R20 value determined during calibration of the PIREG-C2 (from V1.01/1.09/1.06). The reference R20 value monitoring function can be used to detect and monitor changes in the R20 value, e.g. due to ageing or wear of the heatsealing band during calibration. In addition, the reference R20 value monitoring can be

used to prevent disturbances caused by interruptions in parallel-connected heatsealing bands from being “calibrated away”. The reference R20 value monitoring only works during calibration.

A command (RHZL) first stores the reference resistance R20 of the heatsealing band as the reference R20 value, e.g. after calibrating a new heatsealing band. A further command (RRUE) activates the reference R20 value monitoring and sets the OK range around the stored reference R20 value. If the currently calibrated R20 value of the controller is outside the OK range, the PIREG-C2 will go to the error state with error 10.

### 3.4.7. Error causes - Display:

Table 1

No.	Error	Actual value output [V]	Alarm-LED (red)	Calibr.-LED (blue)	Alarm-Output	
					after Reset	after “Start” signal
	Symbols: ○ : off / not set      ● : flashing 1Hz ● : on / set              ◐ : flashing 4Hz					
1	- Device error or - Bus system supply voltage too low or too high	4.66 / 0	●	○		●
2	- Internal error, - Read-write error in the non-volatile memory, - “Start” signal during calibration or - Heating time limit	4.00	●	○		●
3	Power line error (under-/overvoltage or line frequency error)	3.33	●	◐		●
4	Current signal Ir and voltage signal Ur too low	2.00	●	◐	○	●
5	Voltage signal Ur too low	1.33	●	◐	○	●
6	Current signal Ir too low	0.66	●	◐	○	●
7	Current and/or voltage signal too high	5.33<>10	◐	◐	○	●
8	- Temperature too low or too high (heating conductor error), - Temperature monitoring, - Heating monitoring or - Temperature jump downwards or upwards	2.66	●	●	○	●
9	- Data error, stored calibration values do not match setting or - Communication monitoring	6.00<>10	◐	◐	○	●
<b>Calibration not possible because</b>						
10	- Current signal Ir and voltage signal Ur are too low or too high, - R20 cannot be determined, - Reference R20 value monitoring, - Phase shift cannot be determined, - P-factor cannot be determined or - P-factor monitoring has triggered	8.00<>10	◐	◐	○	●
11	- Voltage signal Ur too low, too high or unstable	7.33<>10	◐	◐	○	●
12	- Current signal Ir too low, too high or unstable	6.66<>10	◐	◐	○	●
13	- Selected reference temperature is too high, - Temperature coefficient correction range exceeded or - Parameter error: continuity and dynamics of the selected temperature coefficients in relation to the temperature range.	8.66<>10	◐	◐	○	●

3.4.8. Error causes - Remedy:

Table 2

No.	Error	Remedy and error areas <sup>n</sup>		
		At the installation	During operation	
1	- Device error	perform reset check controller <b>1</b>		
	- Bus system supply voltage too low or too high	check bus system supply voltage perform reset		
2	- Internal error, - Read-write error in the non-volatile memory, - "Start" signal during calibration or - Heating time limit	perform reset check controller <b>1</b> → 4.3.1. → 3.4.5.		
	3	Power line error (under-/overvoltage or line frequency error)	check 120/240V mains voltage changeover (→ 7.2.) check mains connection <b>2</b> perform reset	check mains connection <b>2</b> perform reset
	4	Current signal I <sub>r</sub> and voltage signal U <sub>r</sub> too low	perform calibration check heating circuit <b>3</b>	check heating circuit <b>3</b>
5	Voltage signal U <sub>r</sub> too low	check connection to voltage measurement U <sub>r</sub> <b>4</b> perform calibration	check connection to voltage measurement U <sub>r</sub> <b>4</b>	
6	Current signal I <sub>r</sub> too low	check connection to current measurement I <sub>r</sub> <b>5</b> perform calibration	check connection to current measurement I <sub>r</sub> <b>5</b>	
7	Current and/or voltage signal too high	check heating conductor <b>6</b> perform calibration	check heating conductor <b>6</b>	
8	- Temperature too low or too high (heating conductor error), - Temperature monitoring, - Heating monitoring or - Temperature jump downwards or upwards	check heating conductor <b>6</b> perform calibration	check heating conductor <b>6</b>	
		→ 3.4.1.		
		→ 3.4.2.		
		check heating conductor connection <b>7</b>		
9	- Data error, stored calibration values do not match setting or - Communication monitoring	perform calibration → 5.4. (KOUÉ)		
	<b>Calibration not possible because</b>			
10	- Current signal I <sub>r</sub> and voltage signal U <sub>r</sub> are too low or too high, - R20 cannot be determined, - Reference R20 value monitoring, - Phase shift cannot be determined, - P-factor cannot be determined or - P-factor monitoring has triggered	check heating conductor connection <b>7</b> check dimensioning <b>8</b> check dimensioning <b>8</b> → 3.4.6. check dimensioning <b>8</b> → 3.4.4.	check heating conductor connection <b>7</b> check dimensioning <b>8</b> check dimensioning <b>8</b> → 3.4.6. check dimensioning <b>8</b> → 3.4.4.	
	11	- Voltage signal U <sub>r</sub> too low, too high or unstable	check connection to voltage measurement U <sub>r</sub> <b>4</b> check heating conductor <b>6</b> check dimensioning <b>8</b>	
	12	- Current signal I <sub>r</sub> too low, too high or unstable	check connection to current measurement I <sub>r</sub> <b>5</b> check heating conductor <b>6</b> check dimensioning <b>8</b>	
	13	- Selected reference temperature is too high, - Temperature coefficient correction range exceeded or - Parameter error: continuity and dynamics of the selected temperature coefficients in relation to the temperature range.	→ 3.1.1. → 3.1.8 and 3.1.9. → 3.1.1.	




Figure 7: Error areas

**3.4.9. Error memory:** The PIREG-C2 has an error memory in which the last 100 error events are stored. The error memory can be read out by command (FESP) and cleared by command (FESL). The respective error event is stored together with the value of the operating hours counter at the time of the error, so it can be linked to a time.

## 4. Operation

The PIREG-C2 offers two means of operation. One is conventional operation with setpoint potentiometer or setpoint voltage, actual value instrument or actual voltage value, switches or digital signals and LEDs. The other is extended operation via EtherNet/IP interface or the RS232 (1), RS485 (2) and USB interfaces (3), with which the PIREG-C2 is equipped. The PIREG-C2 can only be set via the EtherNet/IP interface or the RS232, RS485 or USB interface. Combinations of both types of operation are possible.

### 4.1. Interface

The setting of the PIREG-C2 is only be possibly by the EtherNet/IP interface or the RS232, RS488 and USB interface. The settings will be done with several commands.

#### 4.1.1. Settings - Commands:

Table 3

No.	Setting	Command
1	Heating ramp	EINS
2	Temperature coefficient	EINS EIPA TK
3	Calibration comparison time	EINS
4	Temperature range	EINS EIPA TB

No.	Setting	Command
5	Calibration type	EINS
6	Transformer type	EINS
7	Reference temperature	EINS EIPA BT
8	8-point Tc correction	EINS
9	Single-point Tc correction	STKA

**4.1.2. Setting 1, heating ramp:** The time value during which the controller adjusts the actual temperature to the target temperature in a linear ramp is set at setting 1. This allows the heating conductor to be heated gradually.

**4.1.3. Setting 2, temperature coefficient setting:** The temperature coefficient of the heating conductor used is set at setting 2.



**Caution (EN):** Using heating conductors with too low a temperature coefficient, or adjusting the controller to a temperature coefficient that is too high, can result in uncontrolled overheating or **melting** of the heating conductor.

**Attention (FR):** Si un conducteur de chaleur est utilisé avec un petit coefficient de température ou qu'un coefficient de température trop grand est réglé sur le régulateur, les conducteurs de chaleur vont chauffer de manière incontrôlée et peuvent aller jusqu'à **fondre**.

The actual value can then not reach the target value and the controller continues to heat continuously. The setpoint voltage must be corrected for heating conductors with a different temperature coefficient or the single-point (→ 3.1.9.) or 8-point Tc correction (→ 3.1.8.) must be carried out.

**Example:** The temperature coefficient of the heating conductor is  $4.3 \times 10^{-4}$  1/K and it cannot be set directly with the DIP switches. The smallest Tc that can be set with DIP switches 3 and 4 is  $7.46 \times 10^{-4}$  1/K. Calculation:  $7.46 / 4.3 = 100 \% / X$ . This gives: nominal value  $X = 57\%$ . The nominal value is not 10 V but rather only = 5.7 V for 300 °C with the  $7.46 \times 10^{-4}$  1/K setting. When the nominal value = 10 V, the controller would try to regulate the temperature at 526 °C instead of at 300 °C.

Using the interfaces, it is possible to set the temperature coefficient of the heating conductor exactly at the PIREG-C2 by commands (EIPA and KONF).

**4.1.4. Setting 2, calibration comparison time:** The temperature comparison time is set at setting 3. During calibration, the resistance of the heating conductor is determined from the reference temperature after the input amplifier has been calibrated. To ensure that the reference resistance value determined is correct, the resistance of the heating conductor is measured again after the calibration comparison time has expired, and compared with the determined reference resistance measured previously. If the difference between both measurements is greater than 1.2% a new calibration process is started. This ensures that calibration of the PIREG-D does not take place during cooling of the heating conductor. By extending the calibration comparison time, changes in the resistance of the heating conductor during cooling can be detected more quickly.

**4.1.5. Setting 4, temperature range:** The working temperature range of the controller is set between 300 and 500 °C with setting 4. The limits for the over- and under-temperatures apply accordingly.

**4.1.6. Setting 5, calibration type:** With the setting 5 the following calibration types are select able:

**New calibration:** If the calibration mode "new-calibration" is chosen, the PIREG-D performs a calibration after every power-on or the signal "Reset". The calibration values are not saved. Calibration can also be started in the OFF or error state with the signal "Calibration Start".

**Calibration storage:** Calibration is only started with the signal "Calibration Start". The signal "Calibration Start" can be applied in the OFF or error state or before power-on. The calibration values are stored in a non-volatile memory and cannot be deleted by a power on or the "Reset" signal. This means that a new calibration must be performed after the heating conductor configuration was changed or modifications were carried out on the transformer. The saved values are then overwritten with the newly determined values.

**4.1.7. Setting 6, transformer type:** The PIREG-C2 is adjusted to the transformer type with setting 6. After power-on or "Reset" signal several unipolar phase controls are applied to the transformer so that the remanence in the iron core of the transformer is brought into a defined position. The angle of current flow of the phase angle control for remanence setting must be matched to the transformer type. The quick switch-on procedure is used for every sealing during which only a few remanence-pulses are applied to the transformer before it is switched on. If the pause between two sealing processes is longer than 10 minutes for toroidal core transformers the number of the remanence pulses of the quick switch-on procedure is doubled. The soft switch-on procedure is used for switching on high-quality transformers without power surges.

**4.1.8. Setting 7, reference temperature:** Setting 7 is used to determine whether calibration is performed with a fixed reference temperature of 20 °C or a variable reference temperature between 0 and 50 °C. The variable reference temperature can also be used to calibrate the heating conductor exactly when the temperature of the heating conductor differs greatly from 20 °C. If the temperature of the heating conductor is measured with a temperature sensor before the start of calibration, the influence of the ambient temperature during calibration can be completely excluded. The variable reference temperature must be preset in the PIREG-C2 as a nominal value prior to the start of calibration.

This can be done with a potentiometer, by the PLC or by an external temperature sensor at the target value input or via the interfaces by command (EIPA and KONF). If the reference temperature of +50 °C is exceeded, then an error message is displayed (error 13). The PIREG-C2 reads the variable reference temperature during the calibration initialisation (→ Figure 1). A nominal value of 50 °C corresponds to 1.66 V in the 300 °C range and 1.0 V in the 500 °C range.

**4.1.9. Setting 8, 8-point Tc correction:** Setting 8 can be used to activate the 8-point Tc correction. With this function, scattering of the heating conductor materials due to the alloys used can be corrected. For the correction process the heating conductor of the PIREG-C2 is automatically heated in eight temperature increments during calibration. The first temperature increment is always 50 °C. The temperature of the eighth temperature increment falls 20 % below the final value of the temperature range. The six other temperature increments are equidistant between these points.

- For the 300°C temperature range the points are: 50, 77, 104, 131, 159, 186, 213 and 240 °C.

- For the 500°C temperature range the points are: 50, 100, 150, 200, 250, 300, 350 and 400 °C.

At each step the actual temperature of the heating conductor is reported back to the PIREG-C2 as a target value or directly as a measured value of the external thermometer from outside. Each individual setting point is checked immediately when a maximum deviation of ±20 % is recorded (error 13). From these measurement points, the PIREG-C2 calculates seven regression lines in order to correct its actual value in relation to the actual temperature of the heating conductor.

**Acknowledgement with voltage:** for 300 °C with 10 V.

**Acknowledgement with potentiometer:** for 300 °C, set the potentiometer at 300 °C.

The correction procedure is controlled by the "Start" signal. The next temperature step is switched to with the rising edge of the signal (heat up) and the externally measured nominal temperature of the heating conductor is adopted by the controller with the falling edge. So that the heating conductor can adopt the temperature exactly after a jump in the nominal value, a dwell time of at least 30 s (system dependent) is needed following a heating phase.

If the external thermometer is used for temperature measurement of the heating conductor and the heating time of the temperature stages is preset, the PIREG-C2 can carry out the 8-point Tc correction automatically (→ 3.1.8.).

The temperature values determined by the PIREG-C2 during 8-point Tc correction can be read out by command (TKEI).

**4.1.10. Setting 9, Single-point Tc correction:** In the OFF state, the single-point Tc correction can be started with the STKA command. The tolerances of the temperature coefficient of the heating conductor can thus be corrected for just one operating point. For this operating point the actual temperature of the heating conductor is reported back to the PIREG-C2 as actual value or directly as measured value of the external thermometer from outside. The single-point Tc correction is carried out outside the standard calibration and is started from the OFF state.

Single-point Tc correction has an OFF and an ON state. After start-up the PIREG-C2 is in the OFF state. When the PIREG-D is in the ON state, the heating conductor is heated to the temperature which was set as target value in the OFF state. A dwell time of at least 30 seconds (depending on the system) is required for the heating conductor to reach the temperature after the heating phase. The single-point Tc correction finishes upon exiting the ON state. The correction procedure is controlled by the "Start" signal. Deviations of up to ±20 % between the calculated actual value temperature and the actual temperature of the heating conductor can be corrected. The single-point Tc correction can only be performed if an 8-point Tc correction was not carried out during calibration. The single-point Tc correction is reset at each calibration.

The single-point Tc correction can be saved by command (STKA) so that it doesn't need to be repeated after a new calibration but only when the heating conductor is replaced.

## 4.2. LEDs

### 4.2.1. Power:



The green Power LED indicates that the PIREG-C2 is connected to the line voltage.

After switching on or resetting, the mains LED flashes at 1Hz for 5s if interface control is selected for the temperature setpoint or setting control, see command KONF.

### 4.2.2. Heat:



The yellow Heat LED is directly connected in parallel to the controller's actuator. The brightness of this LED is directly proportional to the energy in the heating conductor.

### 4.2.3. Calibration:



The blue calibration LED lights continuously during calibration and is used for indicating errors. If there is a connection to the external thermometer during calibration or the single-point Tc correction, the LED will flash with 1 Hz.

### 4.2.4. Alarm:



The red Alarm LED, together with the yellow calibration LED, indicates resistance temperature controller errors.

### 4.2.5. Bus system:



The two-colour, green and red LED bus system indicates the following states of the EtherNet/IP interface used as bus system in the PIREG-C2:

Off: No bus system supply voltage  
 Green: Control by a scanner in RUN state  
 Green, flashing: Not configured or the scanner is in IDLE state  
 Red: Grave error (EXCEPTION state, serious error, etc.)  
 Red, flashing: Resettable error. Bus system is configured, but the stored parameters differ from the parameters currently in use.

### 4.2.6. Network:




The two-colour green and red LED network indicates the following states of the bus system network:

Off: No bus system supply voltage or no IP address  
 Green: Online, one or more connections are established (CIP class 1 or 3)  
 Green, flashing: Online, no connection is established  
 Red: Duplicate IP address, serious error  
 Red, flashing: One or more connections have a timeout (CIP class 1 or 3)

## 4.3. Inputs

### 4.3.1. Start input:




The sealing process is initiated by applying a high signal to the start input (6). The controller begins to set the temperature of the heating conductor to the set value temperature and maintains this temperature constantly as long as a high signal is applied to the start input.

If 8-point Tc correction is selected for calibration, the correction process is also controlled by the start input for manual operation. The single-point Tc correction is also controlled by the start input.

During calibration steps 1 to 7, the "Start" signal must not be given, because the PIREG-C2 will then abort the calibration with error 2.


### 4.3.2. Calibration start input:



When a high signal is applied to the calibration start input (5) in the OFF or error state of the controller, it switches to the calibration state. Normally the controller is adapted to the sealing transformer/heating conductor combination. During calibration of the controller the signal can be switched back to Low.


The calibration start input can also be configured for pulse control by command (KONF). The single-point Tc correction can be started in this way in the OFF state when a high signal is applied to the calibration start input for less than one second. If the high signal is applied for more than one second, the PIREG-C2 switches in the calibration state.

#### 4.3.3. Reset input:






When a high signal is applied to the reset input (7), the PIREG-C2 is reset to the state after power-on. This allows you to leave the error state without switching off the mains voltage. It can also be used to cancel a calibration in progress.

#### 4.3.4. Target value input:



The temperature set value of the controller is applied to the target value input (16) with an analogue voltage. For a calibration with variable reference temperature, the reference temperature is applied to the target value input and for the 8-point and single-point T<sub>c</sub> correction, the actual temperature of the heating conductor is applied. The voltage range of the target value input is 0 - 10 V. The selected temperature range applies to the maximum target voltage i.e. 10 V at the target value input correspond to 300 °C or 500 °C in the temperature range 300 °C or 500 °C.



A potentiometer can also be used for the setpoint, whose sliding contact is connected to the target value input, the CW connection to the Uref output (15) and the CCW connection to the corresponding GND connection (13 or 14). When connecting the setpoint potentiometer, pay attention to the direction of rotation of the potentiometer. The voltage at the target value input should increase when turning the setpoint potentiometer clockwise (CW).

### 4.4. Outputs

**4.4.1. Uref output:** The Uref output (15) provides a reference voltage of +10 V needed to obtain the set value using a potentiometer. Should the PIREG-C2 be operated without an additional power supply, the switches for the control inputs can also be connected to the Uref output. The Uref output can supply a maximum current of 20 mA.

**4.4.2. Actual value output:** The actual value output (17) supplies a voltage in the range 0 - 10 V, proportional to the temperature of the heating conductor. The voltage range relates to the selected temperature range. In other words, 10 V at the target value input corresponds to 300 °C or 500 °C. The actual value output can supply a current of max. 5 mA.

**- Hold mode:** When the Hold mode is activated by command (KONF), the temperature measured at the end of the sealing process is also displayed at the actual value output in the OFF state. You can select whether the measured temperature is only displayed for 2 seconds or until the following sealing process is started.

**4.4.3. Alarm output:** The alarm output (12/18) is a relay switching contact. A command (KONF) can be used to set whether the alarm output is opened or closed in the case of a fault. The factory setting of the relay contact is “closed” when a fault occurs. In the event of a power line error (error 3), it is set with a delay of 2 s, for all other errors immediately.

In addition, the SKONF command can be used to specify whether the alarm output should be set immediately in the event of an error or only after the sealing process has been performed. This way, a calibration error does not lead to a machine malfunction when switching on.

**4.4.4. OK output:** The OK output (21/22) is a relay switching contact. A command (KONF) can be used to set whether the OK output is opened or closed if the situation is OK. When supplied from the factory, the relay contact is closed in the OK case. The OK output has the following actuation functions, which can be specified by command (KONF):

- **Calibration OK message:** This is the factory setting. The OK output is reset during calibration. It is set again after a successful calibration. End of calibration is indicated with the calibration OK message. If the stored calibration values do not match the setting, the OK output is also reset.

- **Temperature OK message:** The OK output is activated if the actual value is within the temperature OK range. The temperature OK range and corresponding stabilising time are set by a specific command (TOKG).

- **Combination of calibration and temperature OK message:** This is the combination of the two functions above. This means that the calibration OK message is sent following a reset or a calibration process, and the temperature OK message is sent after the first "Start" signal.

- **Temperature reached message:** If the actual value reaches 95% of the setpoint temperature in the ON state, the OK output is activated. When leaving the ON state, the OK output is reset.

**4.4.5. ELR output:** The ELR output (19/20) controls an external solid-state relay which is used as actuator instead of the internal actuator of the controller. Combinations of heating conductor and sealing transformer which have a greater capacity than the maximum permissible capacity of the internal actuator can be switched with the external solid-state relay.

## 5. Operation

The PIREG-C2 possesses three serial interfaces. These are an RS232 (1), an RS485 (2) and a USB interface (3). The RS232 and RS485 interfaces use a common connector. The USB interface is used as a virtual RS232 interface.

The RS232 and the USB interface are used for direct communication with the controller. The RS485 interface is used as the interface to superordinate controls, e.g. a PLC.

### 5.1. Communication

**5.1.1. RS232 and USB communication:** The RS232 and the USB interfaces use the same command set, which consists of alphanumeric characters. This makes it easily understandable by the user. Every interface has a 64-byte data memory. The Baud rate can be set separately for each interface by command (BRAT). As a factory default setting, both interfaces have the following data format:

9600 Baud                      1 start bit                      8 data bits                      1 stop bit                      no parity

**Protocol:** ASCII characters are used for the communication telegrams. Both large and small letters may be used. The PIREG-C2 does not initiate any communication by itself to its communication partner, it behaves passively. The PIREG-C2 acknowledges every communication from its partner either with the response required or with the OK acknowledgement. There is an error acknowledgement in the event of defective communication. For its acknowledgements and responses, the PIREG-C2 only uses large letters. A telegram always ends with the ASCII character number 13. The names of the commands or acknowledgements are separated from the following data by a blank space. The data to be transferred are transmitted with a constant width and, if necessary, with leading zeros. If several data are transmitted, they are separated by blank spaces.

**5.1.2. Addressed RS232 communication:** Communication via the RS232 interface can also be addressed. This allows the RS232 interfaces of up to three PIREG-C2 to be connected in parallel. In this way, a communication partner can communicate with up to three PIREG-C2 via an RS232 interface. The addressing of the RS232 communication is switched on and off by command (KOKO). The address of the RS232 communication is set by command (GADR) and is also used for RS485 communication. The space for addresses covers the 0 - 250 range. The factory setting is 0.

**Protocol:** The form described above is used for the telegrams of addressed RS232 communication. The address is placed before the command, the acknowledgement and the response and separated by a blank space. Three digits are always used for the address.

**5.1.3. RS485 communication:** The RS485 interface uses a binary command set to increase the rate of communication. The interface has a 64-byte data memory. The PIREG-C2 has an address for RS485 communication that can be set by a command (GADR). This address is also used for addressed RS232 communication. This addressing means that up to 31 PIREG-C2 can be operated on the same RS485 bus. The space for addresses covers the 0 - 250 range. The Baud rate can be set by command (BRAT). The address 0 is the factory setting and the interface has the following data format:

9600 Baud                      1 start bit                      8 data bits                      1 stop bit                      even parity

**Protocol:** The protocol used is based on DIN 19244. The PIREG-C2 does not initiate any communication by itself to the master in the bus system, it behaves passively. The PIREG-C2 responds with a minimum delay of 3 ms for a secure change of direction of the RS485 communication. The following telegram formats are used:

**Short set:** Short sets are sent from the master (on the calling side) to the PIREG-C2:  
→ to transmit short commands to the PIREG-C2 (e.g. reset).  
→ to quickly call up important data from the PIREG-C2.  
Short sets are used (on the response side) by the PIREG-C2:  
→ to acknowledge call ups that do not require any response data.

SZ	GA	FF	PS	EZ
----	----	----	----	----

**Control set:** Control sets are only used by the master on the call-up side. They are used to call up all the commands that cannot be called up by means of short sets because a more detailed specification is required for them. The control set has a fixed length (LG) of three.

SZ	LG	LG	SZ	GA	FF	BI	PS	EZ
----	----	----	----	----	----	----	----	----

**Long set:** Long sets are used:  
→ to transfer commands with parameters to the PIREG-C2  
→ to permit the master to take over data from the PIREG-C2.  
The length (LG) of the long set is the length of the data block plus three.

SZ	LG	LG	SZ	GA	FF	BI	DB0...n	PS	EZ
----	----	----	----	----	----	----	---------	----	----

**Start character SZ:** The start character indicates the telegram (1 byte,)  
 → Start character for short set: 10h  
 → Start character for control set and long set: 68h

**Device address GA:** → 0- 250 range for the individual device addresses of the PIREG-C2. The address 0 is the factory setting.  
 → 255, at this address, all the PIREG-C2s connected to a bus can be addressed at the same time. The data and commands transferred by this address are taken over by all the devices. There is no acknowledgement to the master, however.  
 The device address GA 255 is also acknowledged for the short set with the function field AAh in the call-up direction.

**Function field FF:** The function field includes  
 → with short sets, the actual information, predefined bit by bit and differing in the call up or response direction.  
 → with control and long sets, the directional and control information for the data block being transferred.

Function coding of the function field (FF) in the call-up direction:

Call-up control:	Code:	Type of set:	Remark:
Reset device	09h	Short set	Only the codes specified are evaluated by the PIREG-C2, invalid codes are answered by an error acknowledgement.
Recognise device. The PIREG-C2 transmits an acknowledgement also in the case of the device address 255.	AAh		
Transmit data to PIREG-C2.	69h	Control and long set	
Querying data from PIREG-C2.	89h		

Function coding of the function field (FF) in the response direction:

Bit no.	Function:	Value:	Assignment:
0...2	Reserved	000	Fixed assignment
3	Command lock	0	Command carried out, PIREG-C2 ready
		1	PIREG-C2 is not ready for this command
4	Command error	0	Command carried out
		1	The function key FF or the command index BI is unknown.
5	Transfer error	0	Call-up telegram is correct
		1	A parity defect has occurred or the checksum PS is defective.
6	Unused	0	0
7	Syntax or parameter error	0	No syntax or parameter error
		1	Syntax or parameter error

**Command index BI:** The command to be carried out is specified by the command index. The PIREG-C2 acknowledges as errors all those command indices that are not assigned to a command.

**Length LG:** The length of the data block DB is variable and depends on the command index BI and the function field FF. The control set has a fixed length of three. With the long set, the length LG consists of the length of the data block plus three.

**Data block DB:** Data block DB may contain parameters and data from and to the PIREG-C2. Negative numbers are displayed as two's complements.

**Checksum PS:** With a short set, the checksum is the sum of the device address GA and function field FF without any overrun summation. With a control set, the checksum is the sum of the device address GA, function field FF and command index BI without any overrun summation. With a long set, the checksum is the sum of all the characters of the device address GA until the last character of the data block DB without any overrun summation.

**Terminator EZ:** The terminator is 16h, for all types of set.

**5.1.4. RS232 communication with the external thermometer:** The external thermometer, DTM3000 (from V1.01/1.16/1.10) or previous TM6, can be connected to the RS232 interface of the PIREG-C2 with a special connection cable. The thermometer TM6 is no longer available. The configuration is setting per command (KOKO). The communication is factory set to thermometer DTM3000. The PIREG-C2 tries to establish a connection with the external thermometer when the 8-point Tc correction is started during

calibration and when the single-point Tc correction is started. While the communication is being triggered, the PIREG-C2 sends the request telegram up to four times to the thermometer if it doesn't receive a valid reply before. The maximum communication setup time results from the transmission interval time. If communication cannot be established, the PIREG-C2 will reset the previous interface configuration. The data format for the communication to the external thermometer is as follows:

	Request telegram	Transmission interval time	Maximum Communication setup time	Baud rate	Data format
DTM3000:	„D“	333 ms	1,11 s	9600 Baud	1 start bit 8 data bits
TM6:	„FCh“	1,5 s	5 s	2400 Baud	1 stop bit no parity

After the communication was established the PIREG-C2 continues to send the request telegram to the thermometer with the transmitting interval time. The communication to the thermometer is monitored. If three successive request telegrams are not answered or three successive answers are faulty, the PIREG-C2 switches in the error state with error 9.

The PIREG-C2 will terminate the communication with the thermometer and reset the previous interface configuration after the 8-point and the single point Tc correction correction are ended.

## 5.2. RS232 and USB interface acknowledgements

### 5.2.1. OK acknowledgement

**Syntax:**           **Acknowledgement:**   **QOK00**

**Description:** With this acknowledgement, PIREG-C2 acknowledges error-free communication during which no response is transmitted.

**Example      Message:**       QOK00

**Reference:** Error acknowledgements

### 5.2.2. Error 1 acknowledgement

**Syntax:**           **Acknowledgement:**   **QFE01**

**Description:** The PIREG-C2 sends this acknowledgement if the received command name is unknown to the controller.

**Example      Message:**       QFE01

**Reference:** OK acknowledgement

### 5.2.3. Error 2 acknowledgement

**Syntax:**           **Acknowledgement:**   **QFE02**

**Description:** The PIREG-C2 transmits this acknowledgement if there is a syntax or parameter error in the telegram of the command received or if the telegram is incomplete.

**Example      Message:**       QFE02

**Reference:** OK acknowledgement

### 5.2.4. Error 3 acknowledgement

**Syntax:**           **Acknowledgement:**   **QFE03**

**Description:** The PIREG-C2 transmits this acknowledgement if the telegram's activities have not yet been approved or if the code number entered is incorrect.

**Example      Message:**       QFE03

**Reference:** OK acknowledgement

### 5.2.5. Error 4 acknowledgement

**Syntax:**           **Acknowledgement:**   **QFE04**

**Description:** The PIREG-C2 transmits this acknowledgement if an error occurs when saving data to the EEPROM memory.

**Example      Message:**       QFE04

**Reference:** OK acknowledgement

### 5.3. RS485 interface acknowledgements

During communication via the RS485 interface, acknowledgement is identified through the function field FF in the response telegram.

#### 5.3.1. OK acknowledgement

**Syntax:**           **Acknowledgement:**   **Function field FF = 00h in the response telegram**

**Description:** The OK acknowledgement is given by setting the function field FF to 00h. This is done directly in the response telegram, either as a long or short set.

**Example      Message:**       10 21 00 21 16                           (short set, GA = 21h)

**Reference:** Error acknowledgements

#### 5.3.2. Command lock

**Syntax:**           **Acknowledgement:**   **Short set, function field FF, bit 3 = 1**

**Description:** The PIREG-C2 transmits this acknowledgement if the telegram's activities have not yet been approved or if the code number entered is incorrect.  
In addition, the PIREG-C2 transmits this acknowledgement if an error occurs when saving data to the EEPROM memory.

**Example      Message:**       10 21 08 29 16                           (short set, GA = 21h)

**Reference:** OK acknowledgements

#### 5.3.3. Command error

**Syntax:**           **Acknowledgement:**   **Short set, function field FF, bit 4 = 1**

**Description:** The PIREG-C2 transmits this acknowledgement if the code of the function field FF or the command index BI is unknown to the controller.

**Example      Message:**       10 21 10 31 16                           (short set, GA = 21h)

**Reference:** OK acknowledgements

#### 5.3.4. Transfer error

**Syntax:**           **Acknowledgement:**   **Short set, function field FF, bit 5 = 1**

**Description:** The PIREG-C2 transmits this acknowledgement if a parity error occurs or if the checksum PS is defective.

**Example      Message:**       10 21 20 41 16                           (short set, GA = 21h)

**Reference:** OK acknowledgements

#### 5.3.5. Syntax or parameter error

**Syntax:**           **Acknowledgement:**   **Short set, function field FF, bit 7 = 1**

**Description:** The PIREG-C2 transmits this acknowledgement if there is a syntax or parameter error in the telegram of the command received or if the telegram is incomplete.

**Example      Message:**       10 21 80 A1 16                           (short set, GA = 21h)

**Reference:** OK acknowledgements

### 5.4. Interface commands

Reading (S...) and writing (L...) commands are available for setting the parameters and for operating and controlling the PIREG-C2. The controller parameters can be set and sealing processes controlled with these commands. The factory settings can be reset with a command (WESE).

At the RS232 and USB interfaces, each telegram of a command begins with the character "S" or "L", depending on the type of command. The response telegrams to read commands begin with the character "A", followed by the name of the command. The response times for read commands are between typically 0.5 ms and a maximum of 1 ms, if nothing else is indicated. The data in the response telegrams are separated by blank spaces.

In addressed RS232 communication, each telegram starts with the address, which consists of three digits, and is separated by a space from the telegram structure of a command, an acknowledgement or an answer described above.

For the RS485 interface, the command for writing is identified with 69h and for reading with 89h in the functional field FF. In the following examples, 21h is used for the controller's device address (GA). The terminator of each telegram at the RS485 interface is 16h.

The limits of the input values are monitored.

## Command overview

L	S	Com.	Description	BI	Item
X	X	<b>AHUE</b>	Setting and querying the settings of the heating monitoring	0Bh	<b>5.4.1.</b>
X	X	<b>BRAT</b>	Setting and querying the baud rate of the interface	0Ah	<b>5.4.2.</b>
X		<b>BSMS</b>	Querying the MAC address and the serial number of the AnyBus module of the bus system of the PIREG-C2 controller	7Bh	<b>5.4.3.</b>
X		<b>BSTZ</b>	Querying the status of the operating hours counter	6Fh	<b>5.4.4.</b>
X	X	<b>EINS</b>	Setting and querying the setting switches of the PIREG-C2	02h	<b>5.4.5.</b>
X	X	<b>EIPA</b>	Setting and querying the setting parameters reference temperature, temperature range and temperature coefficients	03h	<b>5.4.6.</b>
X	X	<b>FEKO</b>	Setting and querying of the settings of the error configuration of the controller	14h	<b>5.4.7.</b>
	X	<b>FESL</b>	Clear the contents of the error memory	6Ch	<b>5.4.8.</b>
X		<b>FESP</b>	Read out the contents of the error memory	76h	<b>5.4.9.</b>
X		<b>FEZU</b>	Querying the error state	33h	<b>5.4.10.</b>
X	X	<b>GADR</b>	Setting and querying the device address GA of the addressed RS232 and RS485 communication	07h	<b>5.4.11.</b>
X		<b>GTYP</b>	Querying the device type of the PIREG-C2 controller	6Bh	<b>5.4.12.</b>
X		<b>GWPA</b>	Querying the selected parameters to be used for the next calibration	04h	<b>5.4.13.</b>
X	X	<b>HZBG</b>	Setting and querying the set maximum heating time	70h	<b>5.4.14.</b>
X		<b>ISTW</b>	Querying the current actual temperature value	34h	<b>5.4.15.</b>
X	X	<b>KANR</b>	Setting and querying the calibration number (1...8) of the active calibration.	3Ch	<b>5.4.16.</b>
X		<b>KAPA</b>	Querying the parameters of the current active calibration	05h	<b>5.4.17.</b>
X		<b>KAPK</b>	Querying the parameters of the calibrated calibration (1...8)	13h	<b>5.4.18.</b>
X	X	<b>KASR</b>	Setting and querying the calibration parameter modulation reserve	10h	<b>5.4.19.</b>
X	X	<b>KOKO</b>	Setting and querying the communication configuration of the controller	11h	<b>5.4.20.</b>
X	X	<b>KONF</b>	Setting and querying the configuration of the PIREG-C2	06h	<b>5.4.21.</b>
X	X	<b>KOUE</b>	Setting and querying the settings of the communication monitoring	0Dh	<b>5.4.22.</b>
X	X	<b>KPFK</b>	Setting and querying the P-factor correction value	0Fh	<b>5.4.23.</b>
X	X	<b>KTKZ</b>	Setting and querying the heating time for the automatic execution of the Tc correction	0Eh	<b>5.4.24.</b>
X	X	<b>MEPA</b>	Setting and querying the state of the measurement pulse-pause	3Dh	<b>5.4.25.</b>
X	X	<b>PFUE</b>	Setting and querying the parameter of the P-factor monitoring	12h	<b>5.4.26.</b>
X	X	<b>RHZL</b>	Setting and querying the reference resistance R20 of the heating conductor	80h	<b>5.4.27.</b>
X	X	<b>RRUE</b>	Setting and querying the parameters of the reference R20 value monitoring	15h	<b>5.4.28.</b>
X	X	<b>SOLW</b>	Setting and querying the temperature setpoint	35h	<b>5.4.29.</b>
X		<b>STEU</b>	Querying the states of the manual and interface control inputs	36h	<b>5.4.30.</b>
	X	<b>STKA</b>	Setting the control states for calibration	38h	<b>5.4.31.</b>
	X	<b>STRS</b>	Setting of the reset	39h	<b>5.4.32.</b>
	X	<b>STST</b>	Setting of the signal start	3Ah	<b>5.4.33.</b>
X		<b>TKEI</b>	Read out the settings of the 8-point Tc correction of the current calibration	72h	<b>5.4.34.</b>
X		<b>TKEK</b>	Read out the settings of the 8-point Tc correction of the of the calibrated calibration (1...8)	73h	<b>5.4.35.</b>
X	X	<b>TOKG</b>	Setting and querying the temperature limits and the stabilisation time of the temperature OK message	08h	<b>5.4.36.</b>
X	X	<b>TUEE</b>	Setting and reading the parameter of the temperature monitoring	09h	<b>5.4.37.</b>
X		<b>UIMW</b>	Querying the samples of Ur and Uir and calculated of the effective values of Ur and Uir	71h	<b>5.4.38.</b>
X		<b>VERS</b>	Querying the device and both program version of the PIREG-C2 controller	69h	<b>5.4.39.</b>
	X	<b>WESE</b>	Setting the factory settings	0Ch	<b>5.4.40.</b>
X		<b>ZPFA</b>	Reading the values of the time log function Off-state	78h	<b>5.4.41.</b>
X		<b>ZPFE</b>	Reading the values of the time log function On-state	79h	<b>5.4.42.</b>
X		<b>ZUST</b>	Querying the state of the PIREG-C2	37h	<b>5.4.43.</b>
X	X	<b>ZYKL</b>	Reset and querying the sealing cycles counter	6Eh	<b>5.4.44.</b>
<b>Shortcuts:</b>					
		L:	Read command	BI:	Command index to RS485 interface
		S:	Write command		

### 5.4.1. AHUE command

**Syntax:** **Read:** **LAHUE**  
**RS232/USB:** Response: - Variant 1: **AAHUE a uuu ooo ttt**  
 - Variant 2: **AAHUE a uuu ooo sss eee**  
**Write:** - Variant 1: **SAHUE a uuu ooo ttt**  
 - Variant 2: **SAHUE a uuu ooo sss eee**  
 Response: OK or error acknowledgement; response time max. 6 ms  
 Release: not in the On or calibration state

**Syntax:** **Read:** **Control set, BI = 0Bh**  
**RS485:** Response: - Variant 1: **Long set with DB0...DB4**

DB4	DB3	DB2	DB1	DB0
H byte	L byte			
ttt		ooo	uuu	a

- Variant 2: **Long set with DB0...DB6**

DB6	DB5	DB4	DB3	DB2	DB1	DB0
H byte	L byte	H byte	L byte			
eee		sss		ooo	uuu	a

**Write:** - Variant 1: **Long set with DB0...DB4, BI = 0Bh**

DB4	DB3	DB2	DB1	DB0
H byte	L byte			
ttt		ooo	uuu	a

- Variant 2: **Long set with DB0...DB6, BI = 0Bh**

DB6	DB5	DB4	DB3	DB2	DB1	DB0
H byte	L byte	H byte	L byte			
eee		sss		ooo	uuu	a

Response: short set, OK or error acknowledgement; response time max. 6 ms

Release: not in the On or calibration state

**Description:** Setting and querying the settings of the heating monitoring. The heating monitoring is a monitoring function with two variants. In variant 1, a maximum time is monitored in which the heating must be carried out. In variant 2, a time range is monitored within which the heating must take place.

With "a" the monitoring function is activated (a=1) and deactivated (a=0). A temperature OK range around the nominal value is set with lower limit "uuu" (5...99K) and upper limit "ooo" (5...99 K) in K. In variant 1, the actual value of the PIREG-C2 must have reached the temperature OK range before the heating time "ttt" has expired in 0.1 s (0 ... 99.9s). In variant 2, the actual value must have reached the temperature OK range within the time window "sss" in 0.1 s (0...99.8s) until "eee" in 0.1 s (0.1...99.9s). Otherwise the PIREG-C2 switches to the error state (error 8).

Monitoring of the heating time is restarted if the set value increases by more than 5°C.

**Example** **Read:** **LAHUE**  
**RS232/USB:** Response: - Variant 1: **AAHUE 1 010 010 010**  
 - Variant 2: **AAHUE 1 010 010 008 012**  
**Write:** - Variant 1: **SAHUE 1 010 010 010**  
 - Variant 2: **SAHUE 1 010 010 008 012**  
 Response: **QOK00**

**Example** **Read:** **68 03 03 68 21 89 0B B5 16** (GA=21h)  
**RS485:** Response: - Variant 1: **68 08 08 68 21 00 0B 01 0A 0A 0A 00 4B 16**  
 - Variant 2: **68 0A 0A 68 21 00 0B 01 0A 0A 08 00 0C 00 55 16**  
**Write:** - Variant 1: **68 08 08 68 21 69 0B 01 0A 0A 0A 00 B4 16** (GA=21h)  
 - Variant 2: **68 0A 0A 68 21 69 0B 01 0A 0A 08 00 0C 00 BE 16**  
 Response: **10 21 00 21 16**

**Reference:** FEZU







**Description:** The command has the function of setting and querying the following setting parameters, which are stored and released by the EINS command:

**Reference temperature BT:**

Setting and querying the reference temperature "ttr" (0...50) in 1 °C for performing the calibration.

**Temperature range TB:**

Setting and querying the parameter only the upper limit "ttr" (100...500) in 1 °C of the temperature range. Each temperature range always starts at 0 °C. The value for the over-temperature limit is always 20 % higher than the upper limit of the temperature range. The value for the under-temperature limit is set at -10 °C.

**Temperature coefficient TK:**

Setting and querying the three coefficients of the heating conductor:

- Tc1= „±aaaa“ in  $0.01 \times 10^{-4} \text{ 1/K}$  (+300...+9999)

- Tc2= „±bbbb“ in  $0.01 \times 10^{-6} \text{ 1/K}^2$  (-9999...+9999)

- Tc3= „±cccc“ in  $0.01 \times 10^{-9} \text{ 1/K}^3$  (-9999...+9999)

At the same time, the PIREG-C2 also checks the progress of the resistance, given by the stored temperature coefficients, for continuity and dynamics in the -20 ...+600 °C temperature range. As a response, the PIREG-C2 provides the temperature range "sss" for continuity and "ddd" for dynamics in °C. The temperature range of the PIREG-C2 must be smaller or, at most, only be equal to the limit temperatures for continuity and dynamics.

**Example RS232/USB:**

**Read:** LEIPA BT Read / write reference temperature  
**Response:** AEIPA BT 030  
**Write:** SEIPA BT 030  
**Response:** QOK00

**Read:** LEIPA TK Read / write temperature coefficients  
**Response:** AEIPA TK +5260 -0646 +0318 500 358  
**Write:** SEIPA TK +5260 -0646 +0318  
**Response:** AEIPA TK 500 358

**Example RS485:**

**Read:** 68 04 04 68 21 89 03 01 AE 16 (GA=21h)  
**Response:** 68 06 06 68 21 00 03 01 1E 00 43 16  
**Write:** 68 06 06 68 21 69 03 01 1E 00 AC 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Read:** 68 04 04 68 21 89 03 03 B0 16 (GA=21h)  
**Response:** 68 0E 0E 68 21 00 03 03 8C 14 7A FD 3E 01 F4 01 66 01 D9 16  
**Write:** 68 0A 0A 68 21 69 03 03 8C 14 7A FD 3E 01 E6 16 (GA=21h)  
**Response:** 68 08 08 68 21 00 03 03 F4 01 66 01 83 16

**Reference:** EINS

**5.4.7. FEKO command**

**Syntax RS232/USB:**

**Read:** LFEKO  
**Response:** AFEKO abcd efgh  
**Write:** SFEKO abcd efgh  
**Response:** OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Syntax RS485:**

**Read:** Control set, BI = 14h  
**Long set with DB0**

DB0							
7	6	5	4	3	2	1	0
h	g	f	e	d	c	b	a

**Write:** Long set with DB0, BI = 14h

DB0							
7	6	5	4	3	2	1	0
h	g	f	e	d	c	b	a

**Response:** OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Description:** Setting and querying of the settings of the error configuration of the PIREG-C2 controller. With the error configuration the following error messages can be activated and deactivated at the PIREG-C2. (from V1.01/1.06/1.06)

### Assignment

- a **Temperature jump:** 0= active 1= deactivated  
b not assigned  
c not assigned  
d not assigned  
e not assigned  
f not assigned  
g not assigned  
h not assigned

**Example** **Read:** LFEKO  
**RS232/USB:** **Response:** AFEKO 1000 0000  
**Write:** SFEKO 1000 0000  
**Response:** QOK00

**Example** **Read:** 68 03 03 68 21 89 14 BE 16 (GA=21h)  
**RS485:** **Response:** 68 04 04 68 21 00 14 01 36 16  
**Write:** 68 04 04 68 21 69 14 01 9F 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Reference:** FEZU

### 5.4.8. FESL command

**Syntax** **Write:** SFESL z

**RS232/USB:** **Response:** OK or error acknowledgement; response time max. 225 ms  
**Release:** not in the On or calibration state

**Syntax:** **Write:** Long set with DB0, BI = 6Ch

**RS485:**

DB0							
7	6	5	4	3	2	1	0
-	-	-	-	-	-	-	Z

**Response:** short set, OK or error acknowledgement; response time max. 225 ms  
**Release:** not in the On or calibration state

**Description:** Clear the contents of the error memory with the status z=1. The PIREG-C2 stores the last 100 error events. After deletion, all values of the memory locations are zero.

**Example** **Write:** SFESL 1  
**RS232/USB:** **Response:** QOK00

**Example** **Write:** 68 04 04 68 21 69 6C 01 F7 16 (GA=21h)  
**RS485:** **Response:** 10 21 00 21 16

**Reference:** FESP

### 5.4.9. FESP command

**Syntax** **Read:** LFESP

**RS232/USB:** **Response:** nnn;hhhhh:mm:ss;abcd efgh (100 times)

**Syntax:** **Read:** Control set, BI = 76h

**RS485:** **Response:** Long set with DB0...DB8 (100 times)

DB8	DB7	DB6	DB5	DB4	DB3	DB2	DB1	DB0
				H byte		M byte		L byte
abcd efgh			ss	mm	hhhhh			nnn

Note: For reasons of downward compatibility, bit "c2" of parameter "C" is in data byte DB8 as bit 4 and bits "d2" and "d3" of parameter "D" are in data byte DB8 as bits 5 and 6. (see FEZU command)

DB7								DB6							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
g3	g2	g1	g0	f1	f0	e1	e0	d1	d0	c1	c0	b1	b0	a1	a0

DB8							
7	6	5	4	3	2	1	0
-	d3	d2	c2	h3	h2	h1	h0

**Description:** Read out the contents of the error memory of the PIREG-C2 controller. The PIREG-C2 stores the last 100 error events. The output is in CSV format. All values are zero for unoccupied memory locations. The output is in 100 lines. The error with the number 1 is the newest error event. The error with the number 100 is the oldest error event. In RS485 communication, the hundred long sets of the response are sent one after the other with a pause of 3ms each.

## Assignment

- nnn:** number of the memory location (1...100)  
**hhhhh:** Operating time hours (0...999999)  
**mm:** Operating time minutes (0...59)  
**ss:** Operating time seconds (0...59)
- a Hardware error:** 0= Ok 1= error  
**b Power line error:** 0= Ok 1= undervoltage  
 2= overvoltage 3= line frequency error  
**c Data error:** 0= Ok  
 1= Calibration values do not suit the setting  
 2= Read/write error in the non-volatile memory  
 3= Communication monitoring  
 4= Heating time limit exceeded  
**d Cal. number:** 1...8, the error occurred when using this calibration  
**e Voltage signal Ur:** 0= Ok 1= too small 2= too large 3= unstable  
**f Current signal Ir:** 0= Ok 1= too small 2= too large 3= unstable  
**g Heating conductor temp.:** 0= Ok 1= too small 2= too large  
**with temperature monitoring:** 3= too small 4= too large  
**with heating monitoring:** 5= heating time exceeded  
 6= heating time fallen below  
**Temperature jump:** 7= downwards 8= upwards  
**h Calibration error:**  
 0= Ok  
 1= Parameter error  
 2= Voltage or current signal defective (see above)  
 3= Error in determining the phase shift  
 4= R20 can not be determined or  
 Reference R20 value monitoring (from V1.01/1.09/1.06)  
 5= Error in determining the P-factor or P-factor monitoring  
 6= The selected reference temperature is too high  
 7= Range of temperature coefficient correction exceeded  
 8= Start signal during calibration  
 9= Data error on access

**Example** **Read:** LFESP  
**RS232/USB:** **Response:** 001;000024:10:00;0001 0120  
 002;000024:09:47;0001 1120  
 ...

**Example** **Read:** 68 03 03 68 21 89 76 20 16 (GA=21h)  
**RS485:** **Response:** 68 0C 0C 68 21 00 76 01 18 00 00 0A 00 40 24 00 1E 16  
 68 0C 0C 68 21 00 76 02 18 00 00 09 2F 40 25 00 4E 16  
 ...

**Reference:** FEZU, FESL

### 5.4.10. FEZU command

**Syntax** **Read:** LFEZU  
**RS232/USB:** **Response:** AFEZU abcd efgh

**Syntax:** **Read:** Control set, BI = 33h  
**RS485:** **Response:** Long set with DB0...DB2

Note: For reasons of downward compatibility, bit "c2" of parameter "C" is in data byte DB2 as bit 4 and bits "d2" and "d3" of parameter "D" are in data byte DB2 as bits 5 and 6.

DB1								DB0							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
g3	g2	g1	g0	f1	f0	e1	e0	d1	d0	c1	c0	b1	b0	a1	a0

DB2							
7	6	5	4	3	2	1	0
-	d3	d2	c2	h3	h2	h1	h0

**Description:** Querying the error state of the PIREG-C2.

**Assignment**

- a Hardware error:** 0= Ok 1= error  
2= undervoltage bus system supply  
3= overvoltage bus system supply
- b Power line error:** 0= Ok 1= undervoltage  
2= overvoltage 3= line frequency error
- c Data error:** 0= Ok  
1= Calibration values do not suit the setting  
2= Read/write error in the non-volatile memory  
3= Communication monitoring  
4= heating time limit exceeded
- d Cal. number:** 1...8, the error occurred when using this calibration
- e Voltage signal Ur:** 0= Ok 1= too small 2= too large 3= unstable
- f Current signal Ir:** 0= Ok 1= too small 2= too large 3= unstable
- g Heating conductor temp.:** 0= Ok 1= too small 2= too large  
**with temperature monitoring:** 3= too small 4= too large  
**with heating monitoring:** 5= heating time exceeded  
6= heating time fallen below
- Temperature jump:** 7= downwards 8= upwards
- h Calibration error:**  
0= Ok  
1= Parameter error  
2= Voltage or current signal defective (see above)  
3= Error in determining the phase shift  
4= R20 can not be determined or  
Reference R20 value monitoring (from V1.01/1.09/1.06)  
5= Error in determining the P-factor or P-factor monitoring  
6= The selected reference temperature is too high  
7= Range of temperature coefficient correction exceeded  
8= Start signal during calibration  
9= Data error on access

**Example RS232/USB:** **Read:** LFEZU  
**Response:** AFEZU 0001 1120

**Example RS485:** **Read:** 68 03 03 68 21 89 33 DD 16 (GA=21h)  
**Response:** 68 06 06 68 21 00 33 40 2A 00 BE 16 (GA=21h)

**Reference:** ZUST

**5.4.11. GADR command**

**Syntax RS232/USB:** **Read:** LGADR  
**Response:** AGADR aaa  
**Write:** SGADR aaa  
**Response:** OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Syntax RS485:** **Read:** Control set, BI = 07h  
**Response:** Long set with DB0

DB0
Addr.
aaa
DB0
Addr.
aaa

**Write:** Long set with DB0, BI = 07h

**Response:** short set, OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Description:** Setting and querying the device address GA "aaa" (0...250) of the addressed RS232 and RS485 communication. The factory setting is "000". If the device address is changed, the acknowledgement is still made with the old device address.







**Assignment Settings:**

- d Calibration comparison time:** 0= 15 s 1= 30 s
- e Calibration type:** 0= new calibration after a power on or reset  
1= calibration storage
- f Transformer type:** 0= sealing transformer with EI or UI-iron core  
1= sealing transformer with toroidal iron core
- g Temperature coefficient correction:**  
0= without temperature coefficient correction  
1= with 8-point Tc correction  
2= with single-point Tc correction  
3= 8-point Tc correction saved  
4= single-point Tc correction saved

**Example RS232/USB:** **Read:** LKAPA  
**Response:** AGWPA 1100 020 300 +1080 +0000 +0000

**Example RS485:** **Read:** 68 03 03 68 21 89 05 AF 16 (GA=21h)  
**Response:** 68 0E 0E 68 21 00 05 03 14 00 2C 01 38 04 00 00 00 00 00 A6 16

**Reference:** GWPA, EINS, STKA

**5.4.18. KAPK command**

**Syntax RS232/USB:** **Read:** LKAPK n  
**Response:** AKAPK n defg bbb ttt ±aaaa ±bbbb ±cccc rrr zzz ppp

**Syntax RS485:** **Read:** Long set with DB0, BI = 13h

DB0
n

**Response:** Long set with DB0...DB15

DB7	DB6	DB5	DB4	DB3	DB2	DB1	DB0
H byte	L byte	H byte	L byte	H byte	L byte		
±aaaa		ttt		bbb		defg	n

DB15	DB14	DB13	DB12	DB11	DB10	DB9	DB8
	H byte	L byte		H byte	L byte	H byte	L byte
ppp	zzz		rrr	±cccc		±bbbb	

DB1							
7	6	5	4	3	2	1	0
-	-	g3	g2	g1	f	e	d

**Description:** Querying the following parameters of the calibrated calibration (1...8) of the PIREG-C2 controller:

- Settings "defg" (see below)
  - Reference temperature "bbb" (0...50, 255 with variable reference temperature) in 1 °C
  - Temperature range "ttt" (100...500) in 1 °C
  - Temp. coeffic. of the heating conductor Tc1 "±aaaa" (+300...+9999) in 0.01x10<sup>-4</sup> 1/K
  - Temp. coeffic. of the heating conductor Tc2 "±bbbb" (-9999...+9999) in 0.01x10<sup>-6</sup> 1/K<sup>2</sup>
  - Temp. coeffic. of the heating conductor Tc3 "±cccc" (-9999...+9999) in 0.01x10<sup>-9</sup> 1/K<sup>3</sup>
  - Modulation reserve "rrr" (000= auto modulation reserve, 20...100 %) in 1 %
  - Heating time for automatic Tc correction "zzz" (0...999 s) in 1 s
  - P-factor correction value "ppp" in % (0, 30...250 % (from V1.01/1.09/1.07))
- If the heating time "zzz" is equal to zero, the Tc correction is controlled via the start input.  
If the P-factor correction value "ppp" is equal to zero, the controller operates with the calibrated P-factor.

**Assignment Settings:**

- d Calibration comparison time:** 0= 15 s 1= 30 s
- e Calibration type:** 0= new calibration after a power on or reset  
1= calibration storage
- f Transformer type:** 0= sealing transformer with EI or UI-iron core  
1= sealing transformer with toroidal iron core
- g Temperature coefficient correction:**  
0= without temperature coefficient correction  
1= with 8-point Tc correction  
2= with single-point Tc correction  
3= 8-point Tc correction saved  
4= single-point Tc correction saved



### Assignment

- a** **Addressed RS232 communication:** 0= Off 1= On
- b** **Communication external thermometer:** 0= Off 1= On  
(from V1.01/1.16/1.10)
- c** **Communication external thermometer type:** 0= DTM3000 1= TM6  
(from V1.01/1.16/1.10)
- d** not assigned
- e** not assigned
- f** not assigned
- g** not assigned
- h** not assigned

**Example RS232/USB:** **Read:** LKOKO  
**Response:** AKOKO 1000 0000  
**Write:** SKOKO 1000 0000  
**Response:** QOK00

**Example RS485:** **Read:** 68 03 03 68 21 89 11 BB 16 (GA=21h)  
**Response:** 68 04 04 68 21 00 11 01 33 16  
**Write:** 68 04 04 68 21 69 11 01 9C 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Reference:** GADR

### 5.4.21. KONF command

**Syntax RS232/USB:** **Read:** LKONF  
**Response:** AKONF abcd efgh  
**Write:** SKONF abcd efgh  
**Response:** OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Syntax RS485:** **Read:** Control set, BI = 06h  
**Response:** Long set with DB0 and DB1

DB1								DB0							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
-	-	-	-	-	-	h1	h0	g	f	e1	e0	d	c	b	a

**Write:** Long set with DB0 and DB1, BI = 06h

DB1								DB0							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
-	-	-	-	-	-	h1	h0	g	f	e1	e0	d	c	b	a

**Response:** short set, OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Description:** Setting and querying the configuration of the PIREG-C2. The configuration determines whether the temperature setpoint of the PIREG-C2 is controlled via the target value input or via the serial interfaces, which setting elements are used, how the alarm and OK outputs are set, whether the pulse control is to be used for the calibration start input and whether the actual value output outputs the actual temperature value or operates as reference voltage source with 10V.

### Assignment

- a** **Temperature nominal value control:**  
0= Manual control via nominal value input (0...10 V)  
1= interface control via RS232, RS485 or USB interface
- b** **Setting control:**  
0= Manual setting via DIP switches (not for PIREG-C2 with bus system)  
1= Interface control with EINS command
- c** **Activation of the alarm output**  
0= Alarm output is only set in the event of a malfunction following initial heating  
1= Alarm output is immediately set in event of a malfunction
- d** **Alarm output switching type:**  
0= relay point closed during alarm  
1= relay point open during alarm

- e OK output activation:**  
 0= Calibration OK message  
 1= Temperature OK message  
 2= Combination of calibration and temperature OK message. The calibration OK message is sent following a reset or a calibration process, and the temperature OK message is sent after the first "Start" signal.  
 3= Temperature reached message.
- f OK output switching type:**  
 0= relay point closed during OK  
 1= relay point open during OK
- g Pulse control of the calibration start input**  
 0= no pulse control  
 1= with pulse control for single-point Tc correction
- h Actual value output feature**  
 0= Actual value output (0...10V)  
 1= 10V reference voltage source  
 0= Hold mode, actual value output (0...10V)  
 0= Hold mode 2s on, actual value output (0...10V)

**Example RS232/USB:**  
**Read:** LKONF  
**Response:** AKONF 0000 0000  
**Write:** SKONF 1100 0000  
**Response:** QOK00

**Example RS485:**  
**Read:** 68 03 03 68 21 89 06 B0 16 (GA=21h)  
**Response:** 68 05 05 68 21 00 06 00 00 27 16  
**Write:** 68 05 05 68 21 69 06 03 00 93 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Reference:** EINS, TOKG

#### 5.4.22. KOUE command

**Syntax RS232/USB:**  
**Read:** LKOU E n  
**Response:** AKOU E n a zzz  
**Write:** SKOU E n a zzz  
**Response:** OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Syntax RS485:**  
**Read:** Long set with DB0, BI = 0Dh

DB0
n

**Response:** Long set with DB0...DB3

DB3	DB2	DB1	DB0
H byte	L byte		
zzz		a	n

**Write:** Long set with DB0...DB3, BI = 0Dh

DB3	DB2	DB1	DB0
H byte	L byte		
zzz		a	n

**Response:** short set, OK or error acknowledgement; response time max. 6 ms  
**Release:** not in the On or calibration state

**Description:** Setting and querying the state of the activation "a" (0=off, 1=on) and the set downtime "zzz" (0...99.9s) in 0.1s of the communication monitoring of the interface with the number "n" (1=RS232, 2=RS485 and 3=USB)  
 The PIREG-C2 controller switches to an error state (error 9) if the communication monitoring is activated and there is no communication via the interface for a time longer than the set downtime.

**Example RS232/USB:**  
**Read:** LKOU E 1 (RS232 interface)  
**Response:** AKOU E 1 1 010  
**Write:** SKOU E 1 1 010 (RS232 interface)  
**Response:** QOK00

**Example RS485:**  
**Read:** 68 04 04 68 21 89 0D 01 B8 16 (GA=21h)  
**Response:** 68 07 07 68 21 00 0D 01 01 0A 00 3A 16  
**Write:** 68 07 07 68 21 69 0D 01 01 A0 00 A3 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Reference:** FEZU















The stabilisation time begins as soon as the actual value has reached the temperature OK range. If the actual value leaves the temperature OK range during the stabilisation time, the temperature OK message is not reset.

The temperature OK message is output with the OK output and is only effective if the temperature OK message was selected with the SKONF command.

**Example**  
**RS232/USB:** **Read:** LTOKG  
 Response: ATOKG 010 010 010  
**Write:** STOKG 010 010 010  
 Response: QOK00

**Example**  
**RS485:** **Read:** 68 03 03 68 21 89 08 B2 16 (GA=21h)  
 Response: 68 07 07 68 21 00 08 0A 0A 0A 00 47 16  
**Write:** 68 07 07 68 21 69 08 0A 0A 0A 00 B0 16 (GA=21h)  
 Response: 10 21 00 21 16

**Reference:** KONF

#### 5.4.37. TUEE command

**Syntax**  
**RS232/USB:** **Read:** LTUEE  
 Response: ATUEE a uuu ooo sss  
**Write:** STUEE a uuu ooo sss  
 Response: OK or error acknowledgement; response time max. 6 ms  
 Release: not in the On or calibration state

**Syntax:** **Read:** Control set, BI = 09h  
**RS485:** Response: Long set with DB0...DB4

DB4	DB3	DB2	DB1	DB0
H byte	L byte			
sss		ooo	uuu	a

**Write:** Long set with DB0...DB4, BI = 09

DB4	DB3	DB2	DB1	DB0
H byte	L byte			
sss		ooo	uuu	a

Response: short set, OK or error acknowledgement; response time max. 6 ms  
 Release: not in the On or calibration state

**Description:** Setting and reading the parameter of the temperature monitoring. The temperature monitoring is a monitoring function, that can be switched on with "a" (a=1) and switched off (a=0). A temperature OK range around the nominal value is set with lower limit "uuu" and upper limit "ooo" in K (5...99 K). If the actual value leaves this range during sealing, once the range has already been reached the PIREG-C2 controller goes into error (error 8). The stabilisation time "sss" in 0.1s (0...99.9 s) begins as soon as the actual value has reached the temperature OK range. If the actual value leaves the temperature OK range during the stabilisation time, the PIREG-C2 controller does not go into error. In the event of a change of the target value by more than 2 °C, the stabilisation period is restarted.

**Example**  
**RS232/USB:** **Read:** LTUEE  
 Response: ATUEE 1 010 010 010  
**Write:** STUEE 1 010 010 010  
 Response: QOK00

**Example**  
**RS485:** **Read:** 68 03 03 68 21 89 09 B3 16 (GA=21h)  
 Response: 68 08 08 68 21 00 09 01 0A 0A 0A 00 49 16  
**Write:** 68 08 08 68 21 69 09 01 0A 0A 0A 00 49 16 (GA=21h)  
 Response: 10 21 00 21 16

**Reference:** FEZU

#### 5.4.38. UIMW command

**Syntax**  
**RS232/USB:** **Read:** LUIMW  
 Response: AUIMW uuuuu vvvvv iiiii ccccc  
 Release: only in OFF and ON state

**Syntax:** **Read:** Control set, BI = 71h  
**RS485:** Response: Long set with DB0...DB7

DB7	DB6	DB5	DB4	DB3	DB2	DB1	DB0
H byte	L byte						
cccc		iiii		vvvv		uuuu	

**Description:** Firstly, the command queries the samples of Ur "uuuuu", in 0.01V, and Uir "iiiiii", in 0.001V, at the sampling time 0.045T before the zero crossing. Secondly, the recalculated effective values of Ur "vvvvv", in 0.01V, and Ir "cccc", in 0.1A, are queried. For the cal-



**Setting parameters (SEIPA):**

Reference temperature: 20°C  
 Temperature range: 200°C  
 Temperature coefficients: Tc1= +3.00 x10-4 1/K, Tc2= -0.01 x10-9 1/K  
 Tc3= -0.01 x10-9 1/K

**Modulation reserve (SKASR):**

Modulation reserve: 20%

**P-factor correction value (SKPFK):**

P-factor correction value: 0 (no P-factor correction value)

**Heating time of auto Tc correction (SKTKZ):**

Heating time: 0 s (no auto Tc correction)

**Setting of calibration 1...8 (LKAPK n):**

all parameters: 0 (clear storage of Tc correction)

**Temperature OK message (STOKG):**

Temperature lower limit: 5 K Stabilisation time: 0  
 Temperature upper limit: 5 K

**Temperature monitoring (STUEE):**

Activation: Off Temperature lower limit: 5 K  
 Stabilization time: 0 Temperature upper limit: 5 K

**Heating monitoring (SAHUE):**

Activation: Off Temperature lower limit: 5 K  
 Heating time: 0 Temperature upper limit: 5 K  
 Variant: 1 (heating time lower limit 1023)

**P-factor monitoring (SPFUE):**

Activation: Off Lower limit: 1  
 Upper limit: 100

**Heating time limit (SHBZG):**

maximum heating time: 0 (Off)

**Reference R20 value monitoring (SRRUE):** (from V1.01/1.09/1.06)

Activation: Off Downward deviation: 5 %  
 Upward deviation: 5 %

**Communication monitoring (SKOUE):**

For all interfaces: Activation: Off Downtime: 0

**Communication configuration (SKOKO):**

Addressed RS232 communication: Off  
 Communication external thermometer: DTM3000 (from V1.01/1.16/1.10)

**Interfaces:**

Baud rate for all interfaces (SBRAT): 9600 Baud  
 Device address for RS485 communication (SGADR): 0

**Setting of controller calibration 1...8 (LTKEK n):**

all parameters: 0

**Counter (SZYKL):**

Calibration cycle counter 1...8: 0

**Error configuration (SFEKO):** (from V1.01/1.06/1.06)

all error messages: active

**Error memory:**

Contents: deleted

**Example** Write: SWESE 1  
**RS232/USB:** Response: QOK00

**Example** Write: 68 04 04 68 21 69 0C 01 97 16 (GA=21h)  
**RS485:** Response: 10 21 00 21 16

**Reference:** --





**Description:** Querying the "zzzzzzz" (0...9999999) sealing cycles performed by the PIREG-C2 for the stored calibrations (parameters "n"=1...8) and the total number of "ggggggggg" (0...999999999) sealing cycles performed by PIREG-C2 with the value zero for the parameter "n".  
 The calibration cycle counters (1...8) are set to zero by transferring the parameter "z" with the respective number (1...8) of the calibration cycle counter.

**Example RS232/USB:** **Read:** LZYKL 0  
**Response:** AZYKL 0 000018553 (total cycle counter)  
**Write:** - Calibration cycle counter: SZYKL 1  
**Response:** QOK00

**Example RS485:** **Read:** 68 04 04 68 21 89 6E 00 18 16 (GA=21h)  
**Response:** 68 07 07 68 21 00 6E 79 48 00 00 50 16  
**Write:** - Calibration cycle counter:  
 68 04 04 68 21 69 6E 01 F9 16 (GA=21h)  
**Response:** 10 21 00 21 16

**Reference:** BSTZ

## 6. EtherNet/IP™ bus system

The PIREG-C2 controller has an EtherNet/IP interface as a bus system for integration into an EtherNet/IP network. An ABCC M40 AnyBus module from HMS is used for the EtherNet/IP interface.

The EtherNet/IP interface of the PIREG-C2 only works as a "slave", so the PIREG-C2 is the "target" (T) and the "master" of the EtherNet/IP network, e.g. a PLC with EtherNet/IP interface, is the "originator" (O). For the EtherNet/IP interface, both cyclic write and read data and acyclic parameter data are used, which can be read and, if possible, written.

### Command overview

Com.	Description	Data type:				Type:	Index:	Item
		LPz	SPz	LPa	SPa			
<b>AHUE</b>	Setting and querying the settings of the heating monitoring			X	X	K	1...5	<b>6.4.1.</b>
<b>BSTZ</b>	Querying the status of the operating hours counter			X		P	6	<b>6.4.2.</b>
<b>EINS</b>	Setting and querying the setting switches of the PIREG-C2			X	X	K	7...14	<b>6.4.3.</b>
<b>EIPA</b>	Setting and querying the setting parameters reference temperature, temperature range and temperature coefficients			X	X	K	15...21	<b>6.4.4.</b>
<b>FEKO</b>	Setting and querying of the settings of the error configuration of the controller			X	X	K	22 23...29	<b>6.4.5.</b>
<b>FEZU</b>	Querying the error state	X				I	--	<b>6.2.1.</b>
<b>GWPA</b>	Querying the selected parameters to be used for the next calibration			X		P	30	<b>6.4.6.</b>
<b>HZBG</b>	Setting and querying the set maximum heating time			X	X	K	31	<b>6.4.7.</b>
<b>ISTW</b>	Querying the current actual temperature value	X				I	--	<b>6.2.1.</b>
<b>KANR</b>	Setting and querying the calibration number (1...8) of the active calibration.	X	X			I/O	--	<b>6.2.1.</b> <b>6.2.2.</b>
<b>KAPK</b>	Querying the parameters of the calibrated calibration (1...8)			X		P	32...39	<b>6.4.8.</b>
<b>KASR</b>	Setting and querying the calibration parameter modulation reserve			X	X	K	40...41	<b>6.4.9.</b>
<b>KONF</b>	Setting and querying the configuration of the PIREG-C2.			X	X	K	42...49	<b>6.4.10.</b>
<b>KPFK</b>	Setting and querying the P-factor correction value			X	X	K	50	<b>6.4.11.</b>
<b>KTKZ</b>	Setting and querying the heating time for the automatic execution of the Tc correction			X	X	K	51	<b>6.4.12.</b>
<b>MEPA</b>	Setting and querying the state of the measurement pulse-pause	X	X			I/O	--	<b>6.2.1.</b> <b>6.2.2.</b>
<b>PFUE</b>	Setting and querying the parameter of the P-factor monitoring			X	X	K	52...55	<b>6.4.13.</b>
<b>RHZL</b>	Setting and querying the reference resistance R20 of the heating conductor			X	X	P	83...85	<b>6.4.14.</b>
<b>RRUE</b>	Setting and querying the parameters of the reference R20 value monitoring			X	X	K	86...88	<b>6.4.15.</b>
<b>SOLW</b>	Setting and querying the temperature setpoint		X			O	--	<b>6.2.2.</b>
<b>STEU</b>	Querying the states of the manual and interface control inputs	X				I	--	<b>6.2.1.</b>
<b>STKA</b>	Setting the control states for calibration		X			O	--	<b>6.2.2.</b>
<b>STRS</b>	Setting of the reset		X			O	--	<b>6.2.2.</b>
<b>STST</b>	Setting of the signal start		X			O	--	<b>6.2.2.</b>
<b>TKEK</b>	Read out the settings of the 8-point Tc correction of the of the calibrated calibration (1...8)			X		P	56...63	<b>6.4.16.</b>
<b>TOKG</b>	Setting and querying the temperature limits and the stabilisation time of the temperature OK message			X	X	K	64...66	<b>6.4.17.</b>
<b>TUEE</b>	Setting and reading the parameter of the temperature monitoring			X	X	K	67...70	<b>6.4.18.</b>
<b>VERS</b>	Querying the device and both program version of the PIREG-C2 controller			X		P	71	<b>6.4.19.</b>
<b>WESE</b>	Setting the factory settings				X	P	72	<b>6.4.20.</b>
<b>ZPFA</b>	Reset and querying the sealing cycles counter			X		P	89	<b>6.4.21.</b>

<b>ZPFE</b>	Reading the values of the time log function ON state			X		P	90	<b>6.4.22.</b>
<b>ZUST</b>	Querying the state of the PIREG-C2	X				I	--	<b>6.2.1.</b>
<b>ZYKL</b>	Reset and querying the sealing cycles counter			X	X	P	73...82	<b>6.4.23.</b>
Data type EtherNet/IP:	LPz: Read process data (T → O, cyclic)							
	SPz: Write process data (O → T, cyclic)							
	LPa: Read parameter data (T → O, acyclic)							
	SPa: Write parameter data (O → T, acyclic)							
Type of the control data:	I: Input data (T → O, cyclic, LPz)							
	O: Output data (O → T, cyclic, SPz)							
	K: Configuration parameter							
	P: Parameter data							

## 6.1. Device data

The PIREG-C2 provides the following device data via the EtherNet/IP interface.

**Read access:** CIP object class: 01h (Identity Object)  
CIP object instance service: 0Eh (Get Attribute Single)

In-stance	Attrib-ute	Data type	Assign-ment:	Description:
1	1	UINT	Vendor ID	060Bh (ODVA manufacturer number)
	2	UINT	Device Type	002Bh (Generic Device)
	3	UINT	Product Code	0064h (Product 1.00)
	4	Struct of USINT USINT	Revision	Version "yy.xx" (e.g. 1.12) of the ABCC M40 module Byte 0: "yy", pre-decimal places, e.g. 01h Byte 1: "xx", post-decimal places, e.g. 0Bh
	5	WORD	Status	Status of the ABCC M40 module (e.g. 0061h) Bit 0: control connection is active (Module Owned) Bit 1: reserved Bit 2: configuration is complete (Configured) Bit 3: reserved Bit 4...7: Extended Device Status: <u>Value:</u> <u>Meaning:</u> 0000b Unknown 0010b Incorrect I/O connection 0011b No I/O connection established 0100b Non-volatile configuration error 0101b Serious error 0110b Connection active (Run mode) 0111b Waiting connection (Idle mode) others reserved Bit 8: Insignificant correctable error Bit 9: Minor unrecoverable error Bit 10: Significant correctable error Bit 11: Significant unrecoverable error (Bit 8...11: see diagnostic object 02h) Bit 12...15: reserved
	6	UDINT	Serial No.	Serial no. of the ABCC M40 module (e.g. A0324FE8h)
	7	SHORT_STRING	Product Name	Product name "PIREG-C2"
	11	Struct of USINT USINT USINT	Active Language	Active language (e.g. German): Byte 0: e.g. "d" (64h) Byte 1: e.g. "e" (65h) Byte 2: e.g. "u" (75h)
	12	Array of Struct of USINT USINT USINT USINT	Supported Language List	List of supported languages: Field 0: Byte 0: e.g. "d" (64h) Byte 1: e.g. "e" (65h) Byte 2: e.g. "u" (75h) (currently only German)

## 6.2. Process data

The process data, which are cyclically transmitted, contains control data, as write process data (WPD, Consuming Data), and states, as read process data (RPD, Producing Data), of the PIREG-C2 in a compact form for fast access.

### 6.2.1. Read process data, T → O

The cyclic read process data (RPD, Producing Data) is transferred from the PIREG-C2 to the control (T → O). The read process data contains the states of the PIREG-C2.

**Read access:**

CIP object class:	04h	(Assembly Object)
CIP object instance service:	0Eh	(Get Attribute Single)
Instance:	64h	(Producing Instance)

In-stance	Attrib-ute	Data type	Assign-ment:	Description:
100 (64h)	3	Array of BYTE	Produced Data	Read process data (RPD, Producing Data), see below
	4	UINT	Size	Number of bytes for the read process data (e.g. 9)

Byte	Assignment:								Description
	7	6	5	4	3	2	1	0	
0	L byte (bits 0...7)								Actual value (0...999 °C) in °C (see ISTW)
1	H byte (bits 8...15)								
2	f	e1	e0	d	-	c	b	a	Control states 1: Assignment of parameters a...f see command STEU
3	MTER Temp. reached	MOK Temp. OK	MOK Cal. OK	z	n3	n2	n1	n0	Control states 2 and messages: Bits 0...3: KANR, Cal. number, n0...3 Bit 4: MEPA, measurement pulse-pause, z Bit 5: MKOK, Calibration OK message Bit 6: MOK, Temperature OK message Bit 7: MTER, Temp. reached message
4	k3	k2	k1	k0	b3	b3	b1	b0	States: Bit 0...3: Operating state, b0...b3 Bit 4...7: Calibration state, k0...k3 Assignm. of parameters b and k see command ZUST
5	-	c2	c1	c0	b1	b0	a1	a0	Error state: Byte 5: Bit 0...1: Hardware error, a0...1 Bit 2...3: Power line error, b0...1 Bit 4...6: Data error, c0...2
6	f1	f0	e1	e0	d3	d2	d1	d0	Byte 6: Bit 0...3: Calibration number, d0...3 Bit 4...5: Voltage signal Ur, e0...1 Bit 6...7: Current signal Ir, f0...1
7	h3	h2	h1	h0	g3	g2	g1	g0	Byte 7: Bit 0...3: Heating conductor temperature, Temperature monitoring, heating monitoring and Temperature jump, g0...3 Bit 4...7: Calibration error, h0...3 Assignment of parameters a...h see command FEZU
8	-	-	-	-	-	-	q1	q0	Communication error: Error during the last communication to PIREG-C2 Bit 0...1: q0...1, communication error no.: 0: OK acknowledgement, see QOK00 1: Syntax or parameter error, see QFE02 2: Access not released, see QFE03 3: Error when saving in EEPROM, see QFE04

### 6.2.2. Write process data, O → T

The cyclic write process data (WPD, Consuming Data) is transferred from the control to the PIREG-C2 (O → T). The write process data contains the control data of the PIREG-C2. The write process data is monitored for the limits and releases specified in the respective command description and discarded in the event of an error.

**Write access:**

CIP object class:	04h	(Assembly Object)
CIP object instance service:	10h	(Set Attribute Single)
Instance:	96h	(Consuming Instance)

In-stance	Attrib-ute	Data type	Assign-ment:	Description:
150 (96h)	3	Array of BYTE	Consumer Data	Write process data (WPD, Consuming Data), see below
	4	UINT	Size	Number of bytes for the read process data (e.g. 4)

Byte	Assignment:								Description
	7	6	5	4	3	2	1	0	
0	L byte (bits 0...7)								Setpoint (0...500 °C) in °C (see SOLW)
1	H byte (bits 8...15)								
2	-	-	-	STRS (z)	k2	k1	k0	STST (z)	Control states: Assignment of parameter ST see command STST Assignm. of parameters k0...2 see command STKA Assignment of parameter RS see command STRS
3	-	-	-	z	n3	n2	n1	n0	Assignment of parameter n0...3 see command KANR Assignment of parameter z see command MEPA

### 6.3. Configuration parameters

In the parameter data, a distinction is made (see 4.11, Access - P / - K) between pure parameter data (P) and configuration parameters (C). The configuration parameters are normally sent to the PIREG-C2 by the parent controller during booting (O → T). The configuration parameters are stored in the PIREG-C2.

**Read access:**

CIP object class:	04h	(Assembly Object)
CIP object instance service:	0Eh	(Get Attribute Single)
Instance:	C8h	(Configuration instance)
Attribute:	3	

**Write access:**

CIP object class:	04h	(Assembly Object)
CIP object instance service:	10h	(Set Attribute Single)
Instance:	C8h	(Configuration instance)
Attribute:	3	

### 6.4. Parameter data

The acyclic read (RPa) and write parameter data (WPa) are read (T → O) or written (O → T) by the control. The write parameter data is monitored for the limits and releases specified in the respective command description and discarded in the event of an error.

**Read access:**

CIP object class:	A2h	(ADI Object)
CIP object instance service:	0Eh	(Get Attribute Single)

**Write access:**

CIP object class:	A2h	(ADI Object)
CIP object instance service:	10h	(Set Attribute Single)

**Configuration parameters:** In the parameter data, a distinction is made between pure parameter data (P) and configuration parameters (C). The configuration parameters are normally sent to the PIREG-C2 by the parent controller during booting. The configuration parameters are initially not stored.

Parameter 90, "Configuration parameters store and restore", can be used to store and restore the configuration parameters in the PIREG-C2.

#### 6.4.1. AHUE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
1				Heating monitoring, activation
	1	SHORT_STRING	Name	"AHUE Aktivierung"
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Activation (0/1)
2				Heating monitoring, temperature lower limit
	1	SHORT_STRING	Name	"AHUE Temp. Ug."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa -C)
	5	USINT	Value	Lower limit (5...99 °C)

<b>3</b>				Heating monitoring, temperature upper limit
	1	SHORT_STRING	Name	"AHUE Temp. Og."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Upper limit (5...99 °C)
<b>4</b>				Heating monitoring, heating time lower limit (Note: only Variant 2)
	1	SHORT_STRING	Name	"AHUE Ah-Zeit Ug."
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa)
	5	UINT	Value	Heating time lower limit (0...998, in 0.1 s)
<b>5</b>				Heating monitoring, heating time upper limit (Note: only Variant 2)
	1	SHORT_STRING	Name	"AHUE Ah-Zeit Og."
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	UINT	Value	Heating time upper limit (1...999, in 0.1 s)

#### 6.4.2. BSTZ parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
<b>6</b>				Operating hours counter
	1	SHORT_STRING	Name	"BSTZ Betriebsst."
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Operating hours counter (0...999999,999 h)

#### 6.4.3. EINS parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
<b>7</b>				Setting switch, Heating ramp of the heating conductor
	1	SHORT_STRING	Name	„EINS Aufheiz-R.“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Heating ramp of the heating conductor (0...3)
<b>8</b>				Setting switch, Tc of the heating conductor
	1	SHORT_STRING	Name	„EINS Tk“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Tc of the heating conductor (0...6) (from V1.01/1.13/1.08)
<b>9</b>				Setting switch, Calibration comparison time
	1	SHORT_STRING	Name	„EINS Kal.-Vergl.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Calibration comparison time (0/1)

10				Setting switch, Temperature range
	1	SHORT_STRING	Name	„EINS Temp.-B.“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Temperature range (0...2)
11				Setting switch, Calibration type
	1	SHORT_STRING	Name	„EINS Kal.-Art“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Calibration type (0/1)
12				Setting switch, Transformer type
	1	SHORT_STRING	Name	„EINS Trafo-Typ“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Transformer type (0/1)
13				Setting switch, Reference temperature
	1	SHORT_STRING	Name	„EINS Bz-Temp.“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Reference temperature (0...2)
14				Setting switch, 8-point Tc correction
	1	SHORT_STRING	Name	„EINS Tk-Korr.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	8-point Tc correction (0/1)

#### 6.4.4. EIPA parameter data

Instance (ADI)	Attribute	Data type	Assignment:	Description:
15	Setting parameter, reference temperature			
	1	SHORT_STRING	Name	“EIPA BT Bz-Temp.”
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Reference temperature (0...50 °C)
16	Setting parameter, temperature range			
	1	SHORT_STRING	Name	“EIPA TB Temp.-B.”
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	UINT	Value	Reference temperature (100...500 °C)
17	Setting parameter, temperature coefficient Tc1			
	1	SHORT_STRING	Name	“EIPA TK Tk1”
	2	USINT	Data type	C3h (INT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	INT	Value	Temperature coefficient Tc1 (+300...+9999)
18	Setting parameter, temperature coefficient Tc2			
	1	SHORT_STRING	Name	“EIPA TK Tk2”
	2	USINT	Data type	C3h (INT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	INT	Value	Temperature coefficient Tc2 (-9999...+9999)

19				Setting parameter, temperature coefficient Tc3
	1	SHORT_STRING	Name	"EIPA TK Tk3"
	2	USINT	Data type	C3h (INT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	INT	Value	Temperature coefficient Tc3 (-9999...+9999)
20				Setting parameter, temperature ranges for continuity
	1	SHORT_STRING	Name	"EIPA ST Temp.-B."
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	01h (RPa - P)
	5	UINT	Value	Temperature ranges for continuity (0...500 °C)
20				Setting parameter, temperature ranges for dynamics
	1	SHORT_STRING	Name	"EIPA DY Temp.-B."
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	01h (RPa - P)
	5	UINT	Value	Temperature ranges for dynamics (0...500 °C)

#### 6.4.5. FEKO Parameterdaten

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
22				Error configuration, Temperature jump
	1	SHORT_STRING	Name	„FEKO Temp.-Spr.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa – C)
	5	USINT	Value	Configuration Temperature jump (0/1)

#### 6.4.6. GWPA parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
30				Parameter selected for the next calibration.
	1	SHORT_STRING	Name	"GWPA Gew. Param."
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	20
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Parameter selected for next calibration: Byte 0: Length Byte 1: not used Byte 2...3: Calibration comparison time (d) Byte 4...5: Calibration type (e) Byte 6...7: Transformer type (f) Byte 8...9: Tc correction (g) Byte 10...11: Reference temperature (bbb) Byte 12...13: Temperature range (ttt) Byte 14...15: Tc1 of heating conductor (±aaaa) Byte 16...17: Tc2 of heating conductor (±bbbb) Byte 18...19: Tc3 of heating conductor (±cccc)

#### 6.4.7. HZBG parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
31				Heating time limit
	1	SHORT_STRING	Name	"HZBG Heizz.-Bg."
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	UINT	Value	Maximum heating time (0...999) in 0.1s

### 6.4.8. KAPK parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
32				Parameter of calibrated calibration 1
	1	SHORT_STRING	Name	"KAPK Par. Kal. 1"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 1: Byte 0: Length Byte 1: not used Byte 2...3: Calibration number, here 1 Byte 4...5: Calibration comparison time (d) Byte 6...7: Calibration type (e) Byte 8...9: Transformer type (f) Byte 10...11: Tc correction (g) Byte 12...13: Reference temperature (bbb) Byte 14...15: Temperature range (ttt) Byte 16...17: Tc1 of heating conductor ( $\pm$ aaaa) Byte 18...19: Tc2 of heating conductor ( $\pm$ bbbb) Byte 20...21: Tc3 of heating conductor ( $\pm$ cccc) Byte 22...23: Modulation reserve (rrr) Byte 24...25: Heating time auto. Tc corr. (zzz) Byte 26...27: P-factor correction value (ppp)
33				Parameter of calibrated calibration 2
	1	SHORT_STRING	Name	"KAPK Par. Kal. 2"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 2: Byte 0: s.a., see instance 32 ... Byte 27
34				Parameter of calibrated calibration 3
	1	SHORT_STRING	Name	"KAPK Par. Kal. 3"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 3: Byte 0: s.a., see instance 32 ... Byte 27
35				Parameter of calibrated calibration 4
	1	SHORT_STRING	Name	"KAPK Par. Kal. 4"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 4: Byte 0: s.a., see instance 32 ... Byte 27
36				Parameter of calibrated calibration 5
	1	SHORT_STRING	Name	"KAPK Par. Kal. 5"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 5: Byte 0: s.a., see instance 32 ... Byte 27

37				Parameter of calibrated calibration 6
	1	SHORT_STRING	Name	"KAPK Par. Kal. 6"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 6: Byte 0: s.a., see instance 32 ... Byte 27
38				Parameter of calibrated calibration 7
	1	SHORT_STRING	Name	"KAPK Par. Kal. 7"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 7: Byte 0: s.a., see instance 32 ... Byte 27
39				Parameter of calibrated calibration 8
	1	SHORT_STRING	Name	"KAPK Par. Kal. 8"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	28
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated parameter of calibration 8: Byte 0: s.a., see instance 32 ... Byte 27

#### 6.4.9. KASR parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
40				Calibration parameters modulation reserve
	1	SHORT_STRING	Name	"KASR Aust.-R. R"
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Modulation reserve (rrr) in % (0, 20...100) Byte 1: calibrated modulation res. (kkk) in % (20...100). Set to zero when writing.
41				Calibration parameters Calibrated modulation re-serve
	1	SHORT_STRING	Name	"KASR Aust.-R. K."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated modulation reserve (kkk) in % (20...100)

#### 6.4.10. KONF parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
42				Configuration, Temperature nominal value control
	1	SHORT_STRING	Name	„KONF Temp.-Soll.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Temperature nominal value control (0/1)
43				Configuration, Setting control
	1	SHORT_STRING	Name	„KONF Einst.-St.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Setting control (1)

44				Configuration, Activation of the alarm output
	1	SHORT_STRING	Name	„KONF Alarm-Ausg.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Activation of the alarm output (0/1)
45				Configuration, Alarm output switching type
	1	SHORT_STRING	Name	„KONF Alarm SArt“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Alarm output switching type (0/1)
46				Configuration, OK output activation
	1	SHORT_STRING	Name	„KONF Ok-Ausg.“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	OK output activation (0...3)
47				Configuration, OK output switching type
	1	SHORT_STRING	Name	„KONF Ok SArt“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	OK output switching type (0/1)
48				Configuration, Pulse control of the calibration start input
	1	SHORT_STRING	Name	„KONF Kal.-Eing.“
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Pulse control of the calibration start input (0/1)
49				Configuration, Actual value output feature
	1	SHORT_STRING	Name	„KONF Istw.-Ausg.“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Actual value output feature (0...3)

#### 6.4.11. KPFK parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
50				P-factor correction, this value will be used for all 8 calibration
	1	SHORT_STRING	Name	„KPFK P-Fak.-Kor.“
	2	USINT	Data type	C7h (UINT, from V1.01/1.15/1.10)
	3	USINT	Data length	2 (from V1.01/1.15/1.10)
	4	USINT	Access	03h (RPa/WPa -C)
	5	USINT	Value	P-factor correction value in % (0, 30...250 % (from V1.01/1.09/1.07))

#### 6.4.12. KTKZ parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
51				Heating time of automatic Tc correction, this value will be used for all 8 calibration
	1	SHORT_STRING	Name	"KTKZ Aufheizzeit"
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
	5	UINT	Value	Heating time for auto. Tc correction in s (0...999)

#### 6.4.13. PFUE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
52				P-factor monitoring, activation
	1	SHORT_STRING	Name	"PFUE Aktivierung"
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Activation (0/1)
53				P-factor monitoring, lower limit
	1	SHORT_STRING	Name	"PFUE Untergrenze"
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	P-factor lower limit (1...99)
54				P-factor monitoring, upper limit
	1	SHORT_STRING	Name	"PFUE Obergrenze"
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	P-factor upper limit (2...100)
55				P-factor monitoring, calibrated P-factor (ppp) of the current calibration (1...8)
	1	SHORT_STRING	Name	"PFUE kal. P-Fak."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibrated P-factor (ppp)

#### 6.4.14. RHZL parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
83				Reference resistance R20 of the heating conductor of the current calibration, current R20 value (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„RHZL R20 akt. K.“
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	01h (LPa - P)
	5	USINT	Value	current R20 value in 0,01Ω (0.01...655.33 Ω, 0: deleted, 65534: overflow)

84				Reference resistance R20 of the heating conductor of the current calibration, Reference R20 value (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„RHZL R20 Ref. K.“
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	01h (LPa - P)
	5	USINT	Value	Reference R20 value in 0,01Ω (0.01...655.33 Ω, 0: deleted, 65534: overflow)
85				Reference resistance R20 of the heating conductor of the current calibration, Reference R20 value save or delete (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„RHZL R20 Kal. SL“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	02h (SPa - P)
	5	USINT	Value	Save (1) or Delete (2)

#### 6.4.15. RRUE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
86				Reference R20 value monitoring, activation (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„RRUE Aktivierung“
	2	USINT	Data type	00h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (LPa/SPa - K)
	5	USINT	Value	Activation (0/1)
87				Reference R20 value monitoring, lower limit
	1	SHORT_STRING	Name	„RRUE Untergrenze“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (LPa/SPa - K)
	5	USINT	Value	Reference R20 value, lower limit, Downward deviation in % (5...100)
88				Reference R20 value monitoring, upper limit
	1	SHORT_STRING	Name	„RRUE Obergrenze“
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (LPa/SPa - K)
	5	USINT	Value	Reference R20 value, upper limit, Upward deviation in % (5...100)

#### 6.4.16. TKEK parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
56				8-point Tc correction of calibration 1 Temperature for controller and heating tape
	1	SHORT_STRING	Name	“TKEK Kal. 1”
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 1: Byte 0: Length Byte 1: not used Byte 2...3: Tc point 0, here 0 Byte 4...5: Temp. of controller (rrrr) in 0.1°C Byte 6...7: Temp. of heat. tape (bbbb) in 0.1°C

				Byte 8...9: Tc point 1, here 1 Byte 10...11: Temp. of controller (rrrr) in 0.1°C Byte 12...13: Temp. of heat. tape (bbbb) in 0.1°C Byte 14...15: Tc point 2, here 2 Byte 16...17: Temp. of controller (rrrr) in 0.1°C Byte 18...19: Temp. of heat. tape (bbbb) in 0.1°C Byte 20...21: Tc point 3, here 3 Byte 22...23: Temp. of controller (rrrr) in 0.1°C Byte 24...25: Temp. of heat. tape (bbbb) in 0.1°C Byte 26...27: Tc point 4, here 4 Byte 28...29: Temp. of controller (rrrr) in 0.1°C Byte 30...31: Temp. of heat. tape (bbbb) in 0.1°C Byte 32...33: Tc point 5, here 5 Byte 34...35: Temp. of controller (rrrr) in 0.1°C Byte 36...37: Temp. of heat. tape (bbbb) in 0.1°C Byte 38...39: Tc point 6, here 6 Byte 40...41: Temp. of controller (rrrr) in 0.1°C Byte 42...43: Temp. of heat. tape (bbbb) in 0.1°C Byte 44...45: Tc point 7, here 7 Byte 46...47: Temp. of controller (rrrr) in 0.1°C Byte 48...49: Temp. of heat. tape (bbbb) in 0.1°C Byte 50...51: Tc point 8, here 8 Byte 52...53: Temp. of controller (rrrr) in 0.1°C Byte 54...55: Temp. of heat. tape (bbbb) in 0.1°C
<b>57</b>				8-point Tc correction of calibration 2 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 2"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55
<b>58</b>				8-point Tc correction of calibration 3 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 3"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55
<b>59</b>				8-point Tc correction of calibration 4 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 4"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55

60				8-point Tc correction of calibration 5 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 5"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55
61				8-point Tc correction of calibration 6 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 6"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55
62				8-point Tc correction of calibration 7 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 7"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55
63				8-point Tc correction of calibration 8 Temperature for controller and heating tape
	1	SHORT_STRING	Name	"TKEK Kal. 8"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	56
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Controller and heating tape temperatures of the 8-point Tc correction of calibration 2: Byte 0 s.a., see instance 56 ... Byte 55

#### 6.4.17. TOKG parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
64				Temperature OK message, temperature lower limit
	1	SHORT_STRING	Name	"TOKG Temp. Ug."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Lower limit (5...99 °C)
65				Temperature OK message, temperature upper limit
	1	SHORT_STRING	Name	"TOKG Temp. Og."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
	5	USINT	Value	Upper limit (5...99 °C)

66				Temperature OK message, stabilisation period
	1	SHORT_STRING	Name	"TOKG Stab.-Zeit"
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
5	UINT	Value	Stabilisation period (0...999, in 0.1 s)	

#### 6.4.18. TUEE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
67				Temperature monitoring, activation
	1	SHORT_STRING	Name	"TUEE Aktivierung"
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
5	USINT	Value	Activation (0/1)	
68				Temperature monitoring, temperature lower limit
	1	SHORT_STRING	Name	"TUEE Temp. Ug."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
5	USINT	Value	Lower limit (5...99 °C)	
69				Temperature monitoring, temperature upper limit
	1	SHORT_STRING	Name	"TUEE Temp. Og."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	03h (RPa/WPa - C)
5	USINT	Value	Upper limit (5...99 °C)	
70				Temperature monitoring, stabilisation period
	1	SHORT_STRING	Name	"TUEE Stab.Zeit"
	2	USINT	Data type	C7h (UINT)
	3	USINT	Data length	2
	4	USINT	Access	03h (RPa/WPa - C)
5	UINT	Value	Stabilisation period (0...999, in 0.1 s)	

#### 6.4.19. VERS parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
70				Device and program versions of the PIREG-C2
	1	SHORT_STRING	Name	"VERS Versionen"
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	8
	4	USINT	Access	01h (RPa - P)
5	UINT	Value	Device and program version Byte 0: Length Byte 1: not used Byte 2...3: Device version in 0.01 (vvv) Byte 4...5: Prog. vers. [G] side in 0.01 (ggg) Byte 6...7: Prog. vers. [M] side in 0.01 (mmm)	

#### 6.4.20. WESE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
72				Setting the factory settings
	1	SHORT_STRING	Name	"WESE Werks. Ein."
	2	USINT	Data type	C1h (BOOL)
	3	USINT	Data length	1
	4	USINT	Access	02h (WPa - P)
5	USINT	Value	Control state (0/1)	

#### 6.4.21. ZPFA parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
89				Time log function Off-state (cooling phase) (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„ZPFA Zeitprotok.“
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	6
	4	USINT	Access	01h (LPa - P)
5	UINT	Value	Value of the Time log function Off-state Byte 0: Length Byte 1: not used Byte 2...3: Actual temperature value in °C (iii) Byte 4...5: Cooling time in 0,01s (aaaaa).	

#### 6.4.22. ZPFE parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
90				Time log function On-state (heating phase) (from V1.01/1.15/1.09)
	1	SHORT_STRING	Name	„ZPFE Zeitprotok.“
	2	USINT	Data type	DAh (SHORT_STRING)
	3	USINT	Data length	14
	4	USINT	Access	01h (LPa - P)
5	UINT	Value	Value of the Time log function On-state Byte 0: Length Byte 1: not used Byte 2...3: Actual temperature value in °C (iii) Byte 4...5: Temperature setpoint in °C (sss) Byte 6...7: Heating-up time in 0,01s (aaaaa) Byte 8...9: Sealing time in 0,01s (hhhhh) Byte 10...11: Average of the actual temperature value in °C (mmm) Byte 12...13: Heating time in 0,01s (ggggg)	

#### 6.4.23. ZYKL parameter data

In-stance (ADI)	Attrib-ute	Data type	Assign-ment:	Description:
73				Total cycle counter
	1	SHORT_STRING	Name	“ZYKL Ges.-Zz.”
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
5	USINT	Value	Total cycle counter (0...99999999)	
74				Cycle counter of calibration 1
	1	SHORT_STRING	Name	“ZYKL Kal.-Zz 1”
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
5	USINT	Value	Calibration cycle counter 1 (0...9999999)	
75				Cycle counter of calibration 2
	1	SHORT_STRING	Name	“ZYKL Kal.-Zz. 2”
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
5	USINT	Value	Calibration cycle counter 2 (0...9999999)	

<b>76</b>				Cycle counter of calibration 3
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 3"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 3 (0...9999999)
<b>77</b>				Cycle counter of calibration 4
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 4"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 4 (0...9999999)
<b>78</b>				Cycle counter of calibration 5
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 5"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 5 (0...9999999)
<b>79</b>				Cycle counter of calibration 6
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 6"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 6 (0...9999999)
<b>80</b>				Cycle counter of calibration 7
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 7"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 7 (0...9999999)
<b>81</b>				Cycle counter of calibration 8
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. 8"
	2	USINT	Data type	C8h (UDINT)
	3	USINT	Data length	4
	4	USINT	Access	01h (RPa - P)
	5	USINT	Value	Calibration cycle counter 8 (0...9999999)
<b>82</b>				Clear the cycle counter of calibrations (1...8).
	1	SHORT_STRING	Name	"ZYKL Kal.-Zz. I."
	2	USINT	Data type	C6h (USINT)
	3	USINT	Data length	1
	4	USINT	Access	02h (WPa - P)
	5	USINT	Value	Calibration cycle counter number (1...8)

## 6.5. EtherNet/IP™ reset

When communicating via the EtherNet/IP interface, the PIREG-C2 has two options for triggering a reset. Either the reset command STRS in the process and parameter data or the reset access (05h) to the identity object (01h) can be used.

For the reset access to the identity object (01h), the two following reset types are available. When both reset types are executed, the PIREG-C2 then carries out its own reset.

Type 0:	Power-on reset
Type 1:	Factory settings

**6.5.1. Power-on reset:** The power-on reset (type 1) sets the EtherNet/IP interface and the PIREG-C2 to the same state as after power-on.

<b>Write access:</b>	CIP object class:	01h	(Identity Object)
	CIP object instance service:	05h	(Reset)
	Instance:	1	
	Attribute:	empty	
	Data:	00h	(1 byte)

**6.5.2. Factory settings:** With the reset for the factory settings (type 2) the settings of the EtherNet/IP interface are reset to the factory settings of HMS. For example, the IP address is also set to zero. The PIREG-C2 performs a power-on reset.

<b>Write access:</b>	CIP object class:	01h	(Identity Object)
	CIP object instance service:	05h	(Reset)
	Instance:	1	
	Attribute:	empty	
	Data:	01h	(1 byte)

## 6.6. Manual IP address

The IP address for the EtherNet/IP interface of the PIREG-C2 can be set either via the EtherNet/IP network or manually on the PIREG-C2 with two rotary coding switches.



The rotary coding switches are used to define the lowest byte of the IP address. The setting of the rotary coding switches is only read directly after switching on or after a reset. The following specifications exist:

**Manual IP address, Base value:** 192.168.001.xxx  
**Subnet-mask:** 255.255.255.000

### Setting of rotary coding switch:

00:	The set IP address is retained or the IP address is set via the EtherNet/IP network.
01...FE:	Set manual IP address with xxx = 001...254 (01...FE <sub>Hex</sub> )
FF:	Reset the PIREG-C2 and EtherNet/IP interface to the factory settings.

## 6.7. EDS file

The EDS file is the electronic data sheet of the EtherNet/IP interface of the PIREG-C2. The EDS file describes which data of the PIREG-C2, and in which form, can be accessed via the EtherNet / IP interface. Access to the data via the EtherNet/IP interface is divided into the following four groups, which are described in the EDS file with their structure. The EDS file is read by the programming environment of the used controllers in order to easily integrate the PIREG-C2 into the programming environment.

- cyclic read process data (RPD, Producing Data), T → O (→ 6.2.1.)
- cyclic write process data (WPD, Consuming Data), O → T (→ 6.2.2.)
- configuration parameters, normally O → T (→ 6.3.)
- acyclic read (RPa, T → O) and write parameter data (WPa, O → T) (→ 6.4.)

The version of the EDS file and the version of the programming of the EtherNet / IP interface of the PIREG-C2 are linked via the revision of the EtherNet/IP interface. The following versions/revisions of the EDS file are available for the PIREG-C2:

- Revision 1.011: 16502\_PIREG-C2\_111\_yymmdd.EDS (until V1.01/1.14/1.10)
- Revision 2.nnn: 16502\_PIREG-C2\_2nnn\_yymmdd.EDS (from V1.01/1.15/1.10)

Remarks      nnn:            running number  
                  yymmdd:        date of year (yy), month (mm) and day (dd)

## 7. Installation and commissioning

Firstly, check that the stated voltage of the PIREG-C power line matches the power line voltage being used, and that the transformer primary current matches the controller's load current capability.



**EN:** For safe operation, the PIREG-C2 resistance temperature controller may only operate in symmetrical TN and TT networks.

**FR:** Pour un fonctionnement sûr, le régulateur de température à résistance PiREG-C2 ne peut être exploité que sur des réseaux symétriques TN et TT.



**EN:** During installation, an overcurrent protection device must be provided in front of the mains input of the PIREG-C2.

The PIREG-C2 must be connected to the mains voltage via an easily accessible and marked isolating device (e.g. switch or circuit breaker).

**FR:** Pour l'installation, un disjoncteur à maximum doit être prévu devant l'entrée du réseau du PIREG-C2.

Le PIREG-C2 doit être raccordé à la tension du réseau via un disjoncteur marqué et facilement accessible (par exemple un interrupteur ou un sectionneur de puissance).



**EN:** Functional earthing: Terminal 27 must be earthed so that the shielding of the Ethernet cables is effective according to the requirements of the Ethernet/IP bus system.

**FR:** Mise à la terre : Afin que le blindage du câble Ethernet fonctionne conformément aux exigences du système Bus Ethernet/IP, la borne 27 doit être raccordée à la terre.

### 7.1. Installation

The PIREG-C2 resistance temperature controller is only suited for use in a switch cabinet. Open operation is not permitted.

The PIREG-C2 is intended to be used in a safety enclosure which should confirm with requirements for protection against the spread of fire, against electrical shock, against mechanical hazards and should have adequate rigidity according to UL 61010-1.

The controller as well as the current transformer are mounted on 35mm mounting rails as per EN 60715 (EN 50022). When mounting the controller, observe a minimum distance of at least 20 mm to adjacent devices and cabling on all sides.

Heat dissipation from neighbouring devices must be taken into account (note the ambient temperature specifications).

### 7.2. 120/240V mains voltage changeover

The PIREG-C2-2xx resistance temperature controller has a manual 120/240V mains voltage changeover. The mains voltage is switched by means of a slide switch which is operated from the outside with a screwdriver. The slide switch can be accessed from the underside of the PIREG-C2 between the ventilation slots.

Depending on the setting, the resistance temperature controller type PIREG-C2-2xx can be operated at both a mains voltage of 100...127 V and a mains voltage of 200...240 V using the mains voltage changeover. The resistance temperature controller type PIREG-C2-4xx has no mains voltage changeover.

The resistance temperature controller type PIREG-C2-2xx is factory-set for a mains voltage of 200...240 V.




**EN:** The manual 120/240V mains voltage changeover may only be operated with a suitable screwdriver when the PIREG-C2 is de-energised.

The 120/240V mains voltage changeover must be set according to the mains voltage used. Non-observance will cause the PIREG-C2 to malfunction or damage the PIREG-C2 if the mains voltage is too high.

**FR:** Le changement de tension de secteur 120/240V ne peut être effectué que lorsque le PIREG-C2 est hors tension et à l'aide d'un tournevis adapté.

Le changement de tension de secteur 120/240V doit être réglé conformément à la tension réseau utilisée. En cas de non-respect, le PIREG-C2 ne fonctionne pas ou il peut être endommagé par une tension de secteur trop élevée.



#### Setting of 120/240V mains voltage changeover:

##### Mains voltage 100...127 V:

Switch in "left" position

##### Mains voltage 200...240 V:

Switch in "right" position

#### View:

Bottom side of the PIREG-C2

### 7.3. Configuring the settings

The following settings can be made via the interfaces:

<b>Heating ramp</b>	<b>Calibration type</b>
<b>Temperature coefficient</b>	<b>Transformer type</b>
<b>Temperature comparison time</b>	<b>Reference temperature</b>
<b>Temperature range</b>	<b>8-point Tc correction.</b>

Prior to initial operation, the correct temperature coefficient must be set for the heating conductor being used. Setting too high a temperature coefficient may lead to overheating or melting of the heating conductor.

In addition, the temperature comparison time, the temperature range, the calibration type and the transformer type must be set. If necessary, the variable reference temperature and the 8-point Tc correction must also be activated. A signal must therefore be applied to the set point input. The setting for the heating ramp can be made before or after calibration.

### 7.4. Connecting the PIREG-C2

The resistance temperature controller must be connected according to the connection diagram, depending on the type of actuator used. It is not necessary to pay attention to the polarity of the current Ir and voltage Ur measurement cables to the heating conductor, nor to how the sealing transformer is connected on the primary or secondary side.



The measurement cable of the Voltage measuring input Ur (8/9) and of the Current measuring input Ir (10/11) may not be interchanged, because an interchange can cause a damage of the Current measuring input Ir.

It is recommended to check the connection of the Voltage measuring input Ur (8/9) and of the Current measuring input Ir (10/11) again before commissioning.

When connecting a target value potentiometer, it is vital to pay attention to the correct phase sequence. In the 0 °C setting, the resistance between terminals 13 and 16 must be 0 Ω.

The measurement cables for voltage measurement Ur must be connected directly to the heating conductor and have to be twisted. ( $\geq 50$  turns/m). The cables from the sealing transformer should be connected to the heating conductor with cable lugs and not with plug-type connections. Ensure that the conductors are of adequate cross-section. No additional components, such as fuses, switches or resistance-loaded ammeters should be integrated in the secondary circuit of the sealing transformer.

### 7.5. Control inputs

Ensure that there are no high signals applied to the reset and start control inputs before the controller is started up for the first time. (If the calibration to an altered heating band is not appropriate, it may overheat).

### 7.6. Connecting to the mains voltage

The green Power LED will light following connection to the mains.

If "new calibration" is chosen as calibration mode, the PIREG-C2 will start the calibration procedure immediately after the power has been switched on and it will adjust the controller to the combination of sealing transformer and heating conductor. The blue Calibration LED will light up and the yellow Heat LED will flash. After successful calibration, the PIREG-C2 will return to the OFF state and be on standby (→ Figure 1).

If "Store calibration" is chosen as calibration mode, the PIREG-C2 will return to the off or error state after the power is switched on and will wait for the "Calibration start" signal. The alarm and calibration LEDs may be off, on or flashing. If there are no errors from 1 to 3 (→ Table 1), then the calibration can be activated.

### 7.7. Burning in the heating conductor

With the sealing tool held open, the heating conductor should best be "burned in" in such a way that the "Start" signal is given and the nominal temperature is slowly increased from zero to the burn-in temperature. The final burn-in temperature should be at least 50°C above the maximum sealing temperature on the heating conductor. The heating conductor should be monitored (initial colours, hot spots). Calibration should be carried out again following burn-in.

The initial slow increase of the target temperature is also recommended if a thermally pretreated heating conductor is used which does not need to be burnt in. In this way the correct temperature conductance of the heating conductor can be monitored. Errors arising during calibration and the selection of the temperature coefficient can be checked without the heating conductor can get overheated or burn up (→ 8.).

### 7.8. When the controller does not work correctly

See point 3.4., point 5.4., point 6.4., point 1.3., point 1.4., point 7.3., point 7.4., point 7.7. and point 8..

## 7.9. Current Transformer



**Caution (EN):** To reduce the risk of electric shock, always open or disconnect circuit from power distribution system (or service) or building before installing or servicing current transformers.

**Attention (FR):** Pour réduire le risque de choc électrique, il faut toujours ouvrir ou déconnecter le circuit du système de distribution électrique (ou du service) du bâtiment avant d'installer ou d'entretenir des transformateurs de courant.



**EN:** The following must be observed when installing the current transformer:

- The current transformers may not be installed in equipment where they exceed 75 percent of the wiring space of any cross-sectional area within the equipment.
- Restrict installation of current transformer in an area where it would block ventilation openings.
- Restrict installation of current transformer in an area of breaker arc venting.
- Not suitable for Class 2 wiring methods and Not intended for connection to Class 2 equipment.
- Secure current transformer and route conductors so that the conductors do not directly contact live terminals or bus.

**FR:** Les points suivants doivent être respectés lors de l'installation du transformateur de courant:

- Le transformateur de courant ne doit pas être installé dans des équipements dans lesquels ils dépassent 75 % de l'espace de câblage de toute section transversale de l'équipement.
- Ne doit pas être installé dans une zone dans laquelle ils bloquent les orifices de ventilation.
- Ne doit pas être installé dans une zone d'évacuation d'arc du disjoncteur.
- Ne convient pas aux méthodes de câblage de la classe 2 et n'est pas destiné à être connecté à des équipements de la classe 2.
- Protéger le transformateur de courant et acheminer les conducteurs de manière à ce qu'ils ne soient pas en contact direct avec des bornes sous tension ou avec le bus.

## 8. The heating conductor

The heating conductor is an important component of the control circuit because it functions both as a temperature sensor and heating element at the same time. Due to the complexity and variety involved, the influence of heating conductor geometry is not discussed here. However, some issues concerning physical and electrical properties will be addressed.

The measurement principle of the resistance temperature controller requires that the heating conductor has a positive temperature coefficient, which is set at the PIREG-C2. The use of a heating conductor with a smaller temperature coefficient than that set on the controller can result in the heating conductor getting overheated or burning up (→ 5.4. and 6.4.). Despite full heating capacity, the actual value cannot reach the target value.

During initial heating of the heating conductor to between 250 and 300 °C, the cold resistance of the heating conductor varies by 2 - 3 % (burn-in effect). This resistance variation results in a zero-point error of 20 - 30 °C. After a few heating cycles, this zero-point error needs to be corrected by a new calibration.

Overheated or burnt-out heating conductors should not be used because of irreversible changes in the temperature coefficients.

A constructional measure to improve the exact temperature control and to increase the lifetime of the heating conductor and the Teflon (PTFE) coating is to copper-plate or silver-plate the heating conductor contacts. This measure ensures that the heating conductor contacts remain cold and allows the controller to measure only where sealing is taking place. The temperature of the heating conductor can only be determined by the PIREG-C2 as the mean of all parts of the heating conductor. If any individual parts of the heating conductor are exposed or otherwise not in contact with any heat dissipating areas, they will heat up faster than those sections of the heating conductor that are able to dissipate their heat. In this case, the temperature reached at these sections will be lower than the temperature displayed by the controller and the sealing performance will be worse.

Calibration of the PIREG-C2 is recommended every time a heating conductor is replaced, in order to correct any tolerances of the heating conductor arising during manufacture. When new heating conductors are used, burn-in will again be necessary.

## 9. Technical data

### 9.1. Controller

<b>Mains voltages:</b>	Terminal L1 (1), L2/N (2), T2 (3) and T1 (4)
<b>Standard:</b>	100 (-15 %) ... 127 V (+10 %) / 200 (-15 %) ... 240 V (+10 %) (Voltage fluctuation: 85 ... 140 VAC / 170 ... 264 VAC) with 120/240V mains voltage changeover (→ 7.2.) Allowable mains supply systems and mains voltage: - Three-phase four-wire system with earthed neutral (symmetrical TN and TT networks) 66/115 V 120/208 V 127/220 V 220/380 V 230/400 V 240/415 V - Single-phase (split-phase) three-wire systems 100/200 V 110/220 V 115/230 V 120/240 V 220/440 V 240/480 V Remarks to voltage value above: - „Outer conductor–neutral conductor“/„Outer conductor–outer conductor“
<b>Option:</b>	380 (-15%) ... 415 V (+10%) Allowable mains supply systems and mains voltage: - Three-phase four-wire system with earthed neutral (symmetrical TN and TT networks) 220/380 V 230/400 V 240/415 V Remarks to voltage value above: - „Outer conductor–neutral conductor“/„Outer conductor–outer conductor“
<b>Mains connection:</b>	Connection between outer and neutral conductor or between two outer conductors, whereby the nominal voltage between outer conductor and earth must not exceed 300V.
<b>Overvoltage category:</b>	III
<b>Mains frequency:</b>	50 - 60 Hz (Frequency fluctuation: 45 ... 65 Hz)
<b>Current consumption:</b>	Terminal L1 (1), L2/N (2), T2 (3) and T1 (4) Nominal current: $I_{max} = 5 \text{ A}$ (Actuator Internal thyristors)
<b>Actuators:</b>	
<b>Internal thyristors:</b>	Actuator with antiparallel thyristors on an internal heat sink in the PIREG-C2 Continuous heating, maximum load current: $I_{max} = 5 \text{ A}$ - 100 % operation factor Impulse heating, maximum load current: $I_{max} = 25 \text{ A}$ - max. 20 % operation factor, resp. - max. 6 s on-time Max. peak current ( $t_{peak} = 10\text{ms}$ ): $I_{TSM} = 500 \text{ A}$ Leakage current in closed state: at 240 V: $I_D = 11 \text{ mA}$ at 415 V: $I_D = 13 \text{ mA}$ Power limit load, integral ( $t=10\text{ms}$ ) $I^2t = 1250 \text{ A}^2\text{s}$ Fusing: The fuse must suffice for the electrical current limits defined above.
<b>External solid-state relay:</b>	Solid-state relay, instantaneous switching Galvanic separation: The galvanic separation between the control (Terminal 19 and 20) and the load circuit (Mains) must be configured as double or reinforced isolation, according to EN 61010 resp. UL 61010. Characteristic values for the solid-state relay: DC no-load voltage load of the PIREG-C2: $U_{HILo} = 5 \text{ V}$ DC internal resistance of the PIREG-C2: $R_{vH} = 18 \Omega$ Maximum supply output current: $I_{HILo} = 30 \text{ mA}$ Maximum allowable switch-on delay: $t_{ein} = 0.2 \text{ ms}$ Maximum allowable switch-off delay: $t_{out} = 0.25 \text{ ms}$ Connection of control circuit at PIREG-C2: Terminal 19 (+) / Terminal 20 (-) Circuit: SELV or PELV circuit
<b>Power consumption:</b>	3 W
<b>Overcurrent protection device</b>	Max. nominal current: $I_{nommax} = 10 \text{ A}$ Fuse types: For a UL-compliant installation, UL 248 or UL 489 overcurrent protection devices should be used. - Miniature circuit breakers acc. to EN 60898 (characteristics B, C, D, K or Z) - Miniature circuit breakers acc. to UL489 (characteristics B, C, D, K or Z) - Fuse gG according to IEC 60269 - Fuse Class CC or Class J according to UL 248 (characteristics Fast-Acting or Time-Delay)
<b>Bus system supply:</b>	Bus system supply 24V (29) and GND (28) are protected against reverse polarity Supply voltage: $U_{BSSnom} = 24 \text{ VDC}$ : 21.6...26.4 VDC; peak voltage 30V Supply current: $I_{BSSmax} = 120 \text{ mA}$ Supply: SELV or PELV circuit Functional earthing: Terminal 27 must be earthed so that the shielding of the Ethernet cables is effective according to the requirements of the Ethernet/IP bus system.
<b>Temperature coefficients:</b>	
<b>Interfaces:</b>	Temp. coefficient 1: $Tc1 = 7.46 \times 10^{-4} \text{ 1/K}$ $Tc2 = 0$ $Tc3 = 0$ (Alloy L) Temp. coefficient 2: $Tc1 = 10.8 \times 10^{-4} \text{ 1/K}$ $Tc2 = 0$ $Tc3 = 0$ (Alloy A20) Temp. coefficient 3: $Tc1 = 48.3 \times 10^{-4} \text{ 1/K}$ $Tc2 = -6.12 \times 10^{-6} \text{ 1/K}^2$ $Tc3 = 2.80 \times 10^{-9} \text{ 1/K}^3$ (NOEX) Temp. coefficient 4: $Tc1 = 8,62 \times 10^{-4} \text{ 1/K}$ $Tc2 = 0$ $Tc3 = 0$ (Alloy M) Temp. coefficient 5: $Tc1 = 12.65 \times 10^{-4} \text{ 1/K}$ $Tc2 = 0$ $Tc3 = -0,70 \times 10^{-9} \text{ 1/K}^3$ (Alloy A20C) Temp. coefficient 6: $Tc1 = 12.55 \times 10^{-4} \text{ 1/K}$ $Tc2 = 0$ $Tc3 = 0$ (Alloy A20D) Temperature coefficient with EIPA TK command $Tc1 = +3.00 \dots$ $Tc2 = -99.99 \dots$ $Tc3 = -99.99$ $+99.99 \times 10^{-4} \text{ 1/K}$ $+99.99 \times 10^{-6} \text{ 1/K}^2$ $+99.99 \times 10^{-9} \text{ 1/K}^3$
<b>Temperature range:</b>	
<b>Interfaces:</b>	Temp. range 1: 0...300 °C Undertemperature -10 °C Overtemperature 360 °C Temp. range 2: 0...500 °C Undertemperature -10 °C Overtemperature 600 °C Temp. range with EIPA TB command $0 \dots U_{nom}$ Undertemperature -10 °C Overtemperature $U_{nom} + 20 \%$ $U_{nom} = 100 \dots 500 \text{ °C}$

<b>Time values (50Hz):</b>	Initialisation:	After power on or reset signal:	500 ms	
	Power interruption:	During an interruption to the line voltage, the PIREG-C2 switches to the error state or starts with a reset once the line voltage has been re-established.	$\geq 80$ ms	
	Reset	Stop heating	5...25 ms	
	Start (heating):	Switch on delay:	7...27 ms	
		Switch off delay:	17...44 ms	
	Remanence setting:	After power on, reset and calibration of EI core transformer:	80 ms	
		After power on, reset and calibration of toroidal core transformer:	300 ms	
		During sealing process with EI core transformers	40 ms	
		During sealing process with toroidal core transformers	80 ms	
		During sealing process with toroidal core transformers with sealing pauses of longer than 10 minutes	160 ms	
		Current conduction angle of EI core transformer:	3.1 ms	
		Current conduction angle of toroidal core transformer:	1.8 ms	
	Calibration start:	Switch on delay:	7...27 ms	
	Calibration:	Max. calibration time temperature comparison time= 15 s:	240 s	
		Max. calibration time temperature comparison time= 30 s:	315 s	
		Temperature comparison time 1 (DIP switch 5 =Off, or interfaces):	15 s	
		Temperature comparison time 2 (DIP switch 5 =Off, or interfaces):	30 s	
	Heat-up ramp:	The heating ramp is selected by interfaces:	without /2 /3 /5 s	
<b>Control inputs:</b>	Start (6), calibr. start (5) and reset input (7) are floating			
	control voltage:	$U_{\text{contr}} = 4...32$ VDC (polarity independent)		
	Max. control voltage:	$U_{\text{contr.max}} = \pm 40$ V		
	Control current:	$I_{\text{contr.}} = 0.5...4.5$ mA		
	Supply:	SELV or PELV circuit		
<b>Target value input:</b>	The input (16) is electrically isolated from the measurement side			
	Target value voltage:	$U_{\text{set value}} = 0...10$ VDC, depending on the set temp. range, corresponds to: 0...300 °C      0...500 °C      0... $U_{\text{nom}}$		
	Max. control voltage:	$U_{\text{set value max}} = 11$ V		
	Max. input current:	$I_{\text{inmax}} = 11$ $\mu$ A		
	Input resistance:	$R_{\text{in}} = 1$ M $\Omega$		
	Supply:	SELV or PELV circuit		
<b>Voltage measuring input:</b>	Signal voltage (8/9):	$U_{\text{r}} = 0.4...120$ V		
	Max. signal voltage:	$U_{\text{rmax}} = 160$ V		
	Max. input current:	$I_{\text{inmax}} = 1,5$ mA		
	Input resistance:	Range 1: $R_{\text{in}} = 105$ k $\Omega$	at $U_{\text{r}} = 11...120$ V*	
		Range 2: $R_{\text{in}} = 13.1$ k $\Omega$	at $U_{\text{r}} = 1.4...11$ V*	
		Range 3: $R_{\text{in}} = 1.67$ k $\Omega$	at $U_{\text{r}} = 0.4...1.4$ V*	
		*: e.g. for Alloy A20, temp. range 300°C		
	Measurement Category:	CAT II		
	Supply:	Secondary circuit provides by the mains voltage (see above, Overvoltage category III). The sealing transformer must be configured according to EN 61558 (VDE 0570) resp. UL 5085 (isolating transformer with reinforced isolation) and UL 61010.		
<b>Current measuring input:</b>	Signal current (10/11):	$I_{\text{r}} = 20...500$ mA $U_{\text{r}} = 0.1...2.5$ V		
	Max. signal current:	$I_{\text{rmax}} = 1500$ mA $U_{\text{rmax}} = 5$ V		
	Input resistance:	$R_{\text{in}} = 5$ $\Omega$ (load resistance)		
	Measurement Category:	CAT II		
	Circuit:	SELV or PELV circuit		
<b>Uref output:</b>	The reference output (15) is electrically isolated from the measurement side and overload-protected.			
	Reference voltage:	$U_{\text{ref}} = 9.9...10.1$ VDC		
	Max. output current:	$I_{\text{refmax}} = 20$ mA		
	Internal resistance:	$R_{\text{i}} = 51.1$ $\Omega$		
	Circuit:	SELV or PELV circuit		
<b>Actual value output:</b>	The actual value output (17) is electr. isolated from the measurement side and overload protected.			
	Actual value voltage:	$U_{\text{actual value}} = 0...10$ VDC, depending on the set temp. range, corresponds to: 0...300 °C      0...500 °C      0... $U_{\text{enn}}$		
	Max. output voltage:	$U_{\text{actual value max}} = 10.1$ VDC		
	Max. output current:	$I_{\text{actual value}} = 5$ mA		
	Internal resistance:	$R_{\text{i}} = 100$ $\Omega$		
	Circuit:	SELV or PELV circuit		
<b>Alarm output:</b>	Reed relay normally open contact (12/18), floating			
	Max. switching capacity (ohmic load):	10 W		
	Max. switching voltage:	60 VDC/ 30 VAC		
	Max. switching current:	0,5 ADC/ 0,35 AAC		
	Nominal load (ohmic load):	50 V / 100 mA		
	Lifetime: electrical	$1 \times 10^7$ at nominal load	$1 \times 10^9$ bei 5V mit 100mA	
	Supply:	SELV or PELV circuit		
<b>Ok output:</b>	Reed relay normally open contact (22/22), floating			
	Max. switching capacity (ohmic load):	10 W		
	Max. switching voltage:	60 VDC/ 30 VAC		
	Max. switching current:	0,5 ADC/ 0,35 AAC		
	Nominal load (ohmic load):	50 V / 100 mA		
	Lifetime: electrical	$1 \times 10^7$ at nominal load	$1 \times 10^9$ bei 5V mit 100mA	
	Supply:	SELV or PELV circuit		
<b>Interfaces:</b>				
<b>RS232 interface:</b>	Format (factory setting):	9600 baud, 1 start bit, 8 data bits, 1 stop bit, no parity		
	Baud rates:	9600 bits/s    19200 bits/s    38400 bits/s    57600 bits/s    115200 bits/s		
	RxD input voltage:	$\pm 25$ V	RxD input resistance:	3...7 k $\Omega$
	TxD output voltage:	$\pm 5$ V with 3 k $\Omega$ load	TxD output resistance:	300 $\Omega$

	Supply:	SELV or PELV circuit
	Connection interface:	RJ-12, 6P6C
<b>RS485 interface:</b>	Format (factory setting):	9600 baud, 1 start bit, 8 data bits, 1 stop bit, even parity
	Baud rates:	9600 bits/s    19200 bits/s    38400 bits/s    57600 bits/s    115200 bits/s
	R input voltage:	±14 V                      R input resistance:            24 kΩ
	T output voltage:	1.5...3 V at 54 Ω
	Reference resistances:	+R/+T signal (A):    5.6 kΩ to +5 V +R/+T signal (B):    5.6 kΩ to GND +R/+T signal (A) to -R/-T signal (B):            2.7 kΩ
	Supply:	SELV or PELV circuit
	Connection interface:	RJ-12, 6P6C
<b>USB interface:</b>	Format:	USB 1.1 and 2.0    Converter from USB to RS232 interface
	RS232 format (fact. set.):	9600 baud, 1 start bit, 8 data bits, 1 stop bit, no parity
	RS232 baud rates:	9600 bits/s    19200 bits/s    38400 bits/s    57600 bits/s    115200 bits/s
	USB input voltage:	-0.5...+3,63V
	Supply:	SELV or PELV circuit
	Controller:	FDTI chip FT230XS    internet: <a href="http://www.ftdichip.com">http://www.ftdichip.com</a>
	Connection interface:	Micro USB 2.0 type B
<b>EtherNet/IP™:</b>	Format:	EtherNet/IP, Generic Device profile
	Data rates:	10/100 Mbit, Full/Half duplex operation
	Connection:	2x RJ45, 2-Port-Switch
	Addressing:	Manuel setting or DHCP
	Function:	Device Level Ring (DLR) Beacon-based Address Conflict Detection (ACD)
<b>EMV (CE):</b>	Interfer. immunity:	IEC 61000-6-2.
	Interfer. emission:	IEC 61000-6-3    To comply with the limit value for interference emission, the PIREG-C2 must not be operated without additional mains filtering and the PE connection (27) must be connected to functional earth.
<b>Connections:</b>	Plug-in screw terminals	
	Clamping range 0.2...2.5 mm <sup>2</sup> (AWG 24...12), tightening torque 0.5...0.6 Nm	
	Material: polyamide, not reinforced, flammability class UL94 V0	
<b>Connecting cable:</b>	Rigid or Flexible	Mains cable:            cross-section 0,82...2,5 mm <sup>2</sup> (AWG 18...12) Control cable:        cross-section 0,2...2,5 mm <sup>2</sup> (AWG 24...12)
	Max. current consumption. 5 A:	minimum temperature rating 70 °C
	Max. impulse current 25 A:	minimum temperature rating 105 °C
<b>Type:</b>	Encapsulated in isolating case	
<b>Housing:</b>	Material: polycarbonate fibre-reinforced, PC-F, flammability class UL94 V0 (no fire protection housing)	
<b>Protection class:</b>	Protection class II	
<b>Pollution class:</b>	2	
<b>Protection type:</b>	IP20*                      (*: not part of the acceptance according to UL 61010)	
<b>Mounting:</b>	fast mounting on 35-mm mounting rails, in accordance with EN 60715 (EN 50022)	
<b>Dimensions (W x H x D):</b>	75 x 102.5 x 105.5 mm	
<b>Installation:</b>	Minimum distance to adjacent devices and cabling on all sides at least 20 mm	
<b>Weight:</b>	560 g	
<b>Shock resistance:</b>	10 g	
<b>Altitude:</b>	max. 2000 m	
<b>Humidity:</b>	Maximum relative humidity 80% at temperatures up to +31°C, decreasing linearly up to 50% relative humidity at +40°C.	
<b>Operating temperature:</b>	Max. current consumption 5 A:	5...50 °C                      Max. impulse current 25 A:    5...40 °C
<b>Storage temperature:</b>	-10...70 °C	
<b>UL file:</b>	E509199	

## 9.2. Current transformer

<b>Type:</b>	PIREG-CT-50	
<b>Max. nom. input current:</b>	500 A	Through hole (Primary circuit)
	Supply:	Secondary circuit provides by the mains voltage (see above, Overvoltage category III). The sealing transformer must be configured according to EN 61558 (VDE 0570) resp. UL 5085 (isolating transformer with reinforced isolation) and UL 61010.
<b>Measurement Category:</b>	CAT II	
<b>Max. operation voltage:</b>	160 V	(Voltage between primary and secondary circuit at non isolated though hole conductor.)
<b>Mains frequency:</b>	50 - 60 Hz	
<b>Max. nom. output voltage:</b>	2,5 V	Terminal 1 and 2 (Secondary circuit)
<b>Max. nom. output current</b>	500 mA	
<b>Maximum load resistor:</b>	5 Ω	
<b>Transformation ratio:</b>	1 : 1000	
<b>Connections:</b>	Plug-in screw terminals	
	Clamping range 0.2...2.5 mm <sup>2</sup> (AWG 24...12), tightening torque 0.5...0.6 Nm	
	Material: polyamide, not reinforced, flammability class UL94 V0	
<b>Connecting cable:</b>	Rigid or Flexible	cross-section 0,2...2,5 mm <sup>2</sup> (AWG 24...12)
<b>Type:</b>	Encapsulated in isolating case	
<b>Housing:</b>	Material: polyamide fibre-reinforced, PA-F: sealing compound: polyurethane, flammability class UL94 V0	
<b>Mounting plate:</b>	Material: polyamide, PA, flammability class UL94 V0	
<b>Pollution class:</b>	2	
<b>Protection type:</b>	IP20*                      (*: not part of the acceptance according to UL 61010)	
<b>Mounting:</b>	fast mounting on 35-mm mounting rails, in accordance with EN 60715 (EN 50022)	
<b>Dimensions (W x H x D):</b>	70 x 42,5 x 103,5 mm	
<b>Weight:</b>	180 g	
<b>Shock resistance:</b>	10 g	

<b>Altitude:</b>	max. 2000 m		
<b>Humidity:</b>	Maximum relative humidity 80% at temperatures up to +31°C, decreasing linearly up to 50% relative humidity at +40°C.		
<b>Operating temperature:</b>	0...50 °C		
<b>Storage temperature:</b>	-10...70 °C		
<b>UL file:</b>	E509199		

### 9.3. Potentiometer

<b>Type:</b>	0...300 °C		
<b>Resistance:</b>	5 kΩ ±5 %	Linearity: ±0.25 %	Temperature coefficient: 50 ppm/°C
<b>Total load capacity:</b>	1.0 W		
<b>Turning angle:</b>	1080 °		
<b>Connections:</b>	soldered fitting		
<b>Type:</b>	open		
<b>Housing:</b>	Glass-fibre reinforced plastic		
<b>Mounting hole:</b>	28.45...28.90 mm		
<b>Pollution class:</b>	2		
<b>Protection type:</b>	IP00		
<b>Dimensions (L x D):</b>	57.4 x 32 mm		
<b>Weight:</b>	51 g		
<b>Humidity:</b>	95 %, no condensation		
<b>Altitude:</b>	max. 2000 m		
<b>Operating temperature:</b>	0...50 °C		
<b>Storage temperature:</b>	-10...70 °C		

### 9.4. Analogue display

<b>Type:</b>	Display 2060 0 - 300 °C		
<b>Scale:</b>	0...300 °C	Accuracy: ±1.5 %	Vertical nominal situation
<b>Input voltage:</b>	0 - 10 VDC		
<b>Input resistance:</b>	10.3 kΩ		
<b>Connections:</b>	soldered fitting		
<b>Type:</b>	open		
<b>Housing:</b>	Glass-fibre reinforced plastic		
<b>Section of front panel:</b>	61.2 x 32.2 mm		
<b>Pollution class:</b>	2		
<b>Protection type:</b>	IP00		
<b>Dimensions (W x H x D):</b>	63 x 50.6 x 51.7 mm		
<b>Weight:</b>	65 g		
<b>Humidity:</b>	95 %, no condensation		
<b>Altitude:</b>	max. 2000 m		
<b>Operating temperature:</b>	0...50 °C		
<b>Storage temperature:</b>	-10...70 °C		


### 9.5. Sealing transformer

The sealing transformer must be configured according to EN 61558 (VDE 0570) resp. UL 5085 (isolating transformer with reinforced isolation). The sealing transformer must not be applied with reduced induction.

### 9.6. External thermometer DTM3000


<b>Type:</b>	The DTM3000 is a handy thermometer for thermocouple sensors.		
<b>Sensor:</b>	Thermocouple type K (NiCr-Ni)		
<b>Measuring range:</b>	-200 °C...+1370 °C		
<b>Accuracy:</b>	±0.1 % Full-Scale (only instrument)		
<b>Resolution:</b>	0.1 °C		
<b>Display:</b>	1-line LCD		
<b>connection:</b>	Miniature flat plug		
<b>RS232 interface:</b>	Format:	9600 baud, 1 start bit, 8 data bits, 1 stop bit, no parity	
	Connection:	Binder series 719, 4 pole	
<b>Supply voltage:</b>	Battery:	9V-Block, size 6F22	
	Lifetime:	approx. 125 h	
<b>Housing:</b>	Plastic (ABS)		
<b>Dimensions (W x H x D):</b>	60 x 120 x 26 mm		
<b>Weight:</b>	130 g		
<b>Operating temperature:</b>	0...60 °C		
<b>Remark:</b>	The thermometer TM6 is no longer available.		

### 9.7. Ordering codes




## 9.8 Housing


### 9.8.1. PIREG-C2 housing




### 9.8.2. Current transformer housing



### 9.8.3. Potentiometer housing



### 9.8.4. Analogue display housing




## 9.9. Spare parts


<b>Terminal 1...4:</b>	Phoenix Contact	GMVSTBW 2,5 HV/ 4-ST-7,62BD1-4	1711127
<b>Terminal 5...11:</b>	Phoenix Contact	MVSTBR 2,5/ 7-ST BD:5-11	1881998
<b>Terminal 12...18:</b>	Phoenix Contact	MVSTBW 2,5/ 7-ST BD:18-12	1882036
<b>Terminal 19...22:</b>	Phoenix Contact	MVSTBW 2,5/ 4-ST BD:19-22	1752094
<b>Terminal 27...29:</b>	Phoenix Contact	MVSTBW 2,5/ 3-ST BD:29-27 MQ	1065489
<b>Terminal 1...2:</b>	Phoenix Contact	MVSTBW 2,5/ 2-ST-5,08 BD:1-2	1722325
<b>Anschluss RJ-12, 6P6C</b>	MH Connectors	MHRJ12-6P6CR	6510-0104-04

## 10. Connection diagrams


### 10.1. Connection diagram for PIREG-C2 with external solid-state relay



### 10.2. Connection diagram for PIREG-C2 with internal thyristors



### 10.3. RS232 / RS485 connection - interface



Connection interface: RJ-12, 6P6C

TxD: Output on PIREG-C2  
 RxD: Input on PIREG-C2

## 11. Application note

### 11.1. Application instructions

The following application instructions are available for the PIREG-C2 which should simply operation of the PIREG-C2.

**8-point Tc correction:** Operation of the 8-point Tc correction, which is an additional component of the calibration of the PIREG-C2 to perform a temperature coefficient correction for the heating conductor (→ 3.1.8.).

**Single-point Tc correction:** Operation of the single-point Tc correction for correcting tolerances of the temperature coefficient of the heating conductor in only one operating point (→ 3.1.9.).

**Ur voltage range extension:** Dimensioning of the voltage divider to expand the measuring range of the Ur input (8/9) for Ur voltages greater than 120V.

## 12. Disposal



**EN:** Do not dispose of the device with household waste! The PIREG-C2 and its components must be disposed of via the local collection points for electronic waste in accordance with the WEEE Directive 2012/19/EU on waste electrical and electronic equipment.

**FR:** Ne pas jeter l'appareil dans les ordures ménagères ! Le PIREG-C2 et ses composants doivent être éliminés conformément à la directive DEEE 2012/19/UE relative aux déchets d'équipements électriques et électroniques via les points de collecte locaux des déchets d'équipements électroniques.



**EN:** Incorrect disposal can pose a risk to the environment. The PIREG-C2, its components and packaging materials must be disposed of in accordance with national waste treatment and disposal regulations.

**FR:** Une élimination incorrecte peut entraîner des risques pour l'environnement. Le PIREG-C2, ses composants et matériaux d'emballage doivent être éliminés conformément aux réglementations nationales en matière de traitement et d'élimination des déchets.

**TOSS**<sup>®</sup> GmbH & Co. KG  
-Verpackungssysteme-  
Danziger Straße 15  
D-35418 Alten-Buseck

Phone: +49 (0) 64 08 - 90 91 - 0  
Fax: +49 (0) 64 08 - 43 55  
E-mail: [info@toss-gmbh.de](mailto:info@toss-gmbh.de)  
Internet: [www.toss-gmbh.de](http://www.toss-gmbh.de)